

***Via Electronic Submittal***

December 17, 2020

Chris O'Connor  
Provincial Officer  
Ministry of the Environment, Conservation and Parks  
Hamilton District Office -119 King Street West, 9<sup>th</sup> Floor  
Hamilton, Ontario L8P 4Y7  
[Chris.O'Connor2@ontario.ca](mailto:Chris.O'Connor2@ontario.ca)

Miroslav Ubovic  
Senior Noise Engineer  
Ministry of the Environment, Conservation and Parks  
Environmental Assessment & Permissions Branch  
135 St. Clair Ave West, 1<sup>st</sup> Floor  
Toronto, Ontario M4V 1P5  
[Miroslav.Ubovic@ontario.ca](mailto:Miroslav.Ubovic@ontario.ca)

**Re: Port Dover & Nanticoke Wind – 2020 Immission Audit Report Results  
Renewable Energy Approval 2869-8VDRCV**

---

Please find attached the 2020 immission audit report, prepared by Aercoustics for the Port Dover and Nanticoke Wind Farm.

The associated I-audit data package (4 excel files) is also included within a OneDrive link provided on the email that accompanied this submittal.

If you have any questions, please contact either Casey Chan at (780) 392-5173 or the undersigned at (780) 392-5183.

Sincerely,



Kent Brandt, EP, CRSP  
Senior Manager, Environment

cc: Michael Durst, MECP  
Jordan Heavenor, Capital Power  
Ashley Rafuse, Capital Power  
Casey Chan, Capital Power  
Duncan Halstead, Aercoustics

## IMMISSION AUDIT REPORT – Project: 14000.07

---

### Port Dover and Nanticoke Wind Farm

665 Concession 5 Walpole, Jarvis, Ontario N0A 1J0


---

Prepared for:

**Capital Power L.P.**

1200 – 10423 101 St. N.W.  
Edmonton, AB  
T5H 0E9

Prepared by:



---

**Dónal Finnerty, Ph.D.**



---

**Duncan Halsted, B.A.Sc., P.Eng.**

December 16, 2020

## Revision History

Version	Description	Author	Reviewed	Date
1.0	Initial Report	DAF	DH	December 16, 2020

## Important Notice and Disclaimer

This report was prepared by Aercoustics Engineering Limited (Aercoustics) solely for the client identified above and is to be used exclusively for the purposes set out in the report. The material in this report reflects the judgment of Aercoustics based on information available to them at the time of preparation. Unless manifestly incorrect, Aercoustics assumes information provided by others is accurate. Changed conditions or information occurring or becoming known after the date of this report could affect the results and conclusions presented. Unless otherwise required by law or regulation, this report shall not be shared with any Third Party without the express written consent of Aercoustics. Aercoustics accepts no responsibility for damages, if any, suffered by any Third Party which makes use of the results and conclusions presented in this report.

## Executive Summary

Aeroustics Engineering Limited was retained by Capital Power Ltd. to conduct a detailed acoustic immission measurement (I-Audit), as requested by the Ministry of the Environment, Conservation and Parks (MECP), to confirm that the Port Dover and Nanticoke Wind Farm is in compliance with MECP sound level limits. The Port Dover and Nanticoke Wind Farm is located in the counties of Haldimand and Norfolk, comprising fifty-eight wind turbine generators, having a total nameplate capacity of one hundred and four megawatts.

The purpose of an I-Audit is to determine the sound level produced by the operation of facility wind turbines following the methodology prescribed in the MECP publication entitled “Compliance protocol for wind turbine noise”, dated April 2017. Sound levels from the facility are then compared to the applicable sound level limits and an assessment of compliance is made in this report.

Measurements for the I-audit began in Spring 2020 at two noise sensitive points of reception having high predicted noise impacts from the facility under study; the two receptors under study are V2820 and R487. Monitoring at V2820 was completed in July, whereas monitoring at R487 was restarted in August after blade issues were discovered and subsequently repaired on the nearby turbines. Monitoring for this receptor was completed in November. The resultant turbine-only sound levels determined at both receptors were found to comply with the applicable MECP sound level limits.



## Table of Contents

<b>1</b>	<b>Introduction</b>	<b>1</b>
<b>2</b>	<b>Background</b>	<b>1</b>
<b>3</b>	<b>Facility Description</b>	<b>2</b>
<b>4</b>	<b>Audit Location</b>	<b>2</b>
4.1	Receptor Selection .....	2
4.1.1	Receptor Selection Criteria .....	2
4.1.2	Prevailing Wind Direction .....	2
4.1.3	Receptor Selection Table .....	3
4.2	Monitoring Location .....	4
4.3	Ambient Environment .....	5
4.3.1	Flora .....	5
4.3.2	Fauna .....	5
4.3.3	Traffic .....	5
4.3.4	Industry .....	6
4.3.5	Other Sources .....	6
<b>5</b>	<b>Audit Methodology</b>	<b>6</b>
5.1	Monitoring Equipment .....	6
5.2	Measurement Parameters .....	7
5.3	Filtering Criteria .....	8
5.3.1	Turbines in Study Area .....	9
5.3.2	Removal of Extraneous Noise .....	10
5.3.3	Representative Ambient Conditions .....	11
5.4	Adjacent Wind Facilities .....	11
5.5	Compliance Criteria .....	12
5.5.1	Sample Size Requirements .....	12
5.5.2	Sound Level Limits .....	12
5.5.3	Tonality .....	13
5.6	Deviations .....	13
5.6.1	Measurement Bandwidth .....	13
5.6.2	Microphone Height – R487 Monitor .....	13
<b>6</b>	<b>Audit Results</b>	<b>14</b>

6.1	Audit Duration.....	14
6.2	Weather Conditions.....	14
6.3	Data Excluded due to Filtering Criteria .....	15
6.4	Measured Sound Levels.....	15
6.5	Sound Level Adjustments.....	17
6.5.1	Tonal Adjustment.....	17
6.6	Turbine-Only Sound Levels .....	18
7	Discussion	19
8	Assessment of Compliance	20
8.1	Assessment Table .....	20
8.2	Statement of Compliance .....	21
9	Conclusion	21
10	References	22

**Appendix A**

Site Details

**Appendix B**

Calibration Certificates

**Appendix C**

Statement from the Operator

**Appendix D**

Supplemental Information

## 1 Introduction

Aercoustics Engineering Limited (“Aercoustics”) has been retained by Capital Power L.P. (“Capital Power”) to complete an Immission Audit (“I-audit”) of the Port Dover and Nanticoke Wind Farm (“PDN Wind Farm”). The PDN Wind Farm operates under Renewable Energy Approval (“REA”) #2869-8VDRCV [1].

This I-audit has been conducted per the methodology outlined in Part D and Part E of the Compliance Protocol for Wind Turbine Noise (“Compliance Protocol”). The Compliance Protocol is an Ontario Ministry of the Environment, Conservation and Parks (“MECP”) document used to evaluate noise from a wind facility at nearby receptors [2].

This report summarizes the results of I-audit testing conducted at two (2) points of reception to the PDN Wind Farm.

## 2 Background

I-audit compliance testing for the PDN Wind Farm was originally conducted in 2014 and 2015 in two phases, per Condition E of the PDN Wind Farm REA. The reports detailing this testing were reviewed by the MECP, and a letter of review (“MECP Letter”) was issued from the MECP to Capital Power in December 2018 recommending two (2) additional I-audits and one additional Emission Audit (“E-audit”) be conducted [3].

Following the MECP Letter and subsequent coordination between Capital Power, Aercoustics, and the MECP, I-audit testing began in the Spring of 2019 at two (2) receptors – V2310 and R203. The result of this testing was determined to be inconclusive [4], due to the elevated ambient noise measured at both receptors overshadowing the turbine sound level.

In response to these findings, Capital Power retained Aercoustics to conduct a survey of the ambient sound levels at several receptors in Summer 2019 to determine two new locations for I-audit testing. The results of this survey were used to select two new receptors – V2820 and R487 – and a summary report with the new proposed receptors was sent to the MECP in September 2019. The new locations were approved by the MECP in April 2020, and I-audit testing began at both locations shortly after.

Testing was completed at V2820 in Spring 2020 with the measurements indicating compliance with the applicable sound level limits. Over the same period, acoustic anomalies were identified during the spring I-audit at R487 which required further investigation and inspections of the turbine blades surrounding R487. After confirming that repair work was required on some of the turbine blades, the repairs were immediately conducted and completed in July 2020. The I-audit testing was restarted in August 2020 at R487 and subsequently completed in November 2020. The I-audit at V2820 was completed without issue in July.

### 3 Facility Description

The PDN Wind Farm is a wind facility located in the counties of Haldimand and Norfolk comprising of fifty-eight (58) wind turbine generators (“turbines”), having a total nameplate capacity of one hundred and four (104.4) megawatts. Each turbine has a hub height of ninety-five (95) metres. The facility has one (1) substation transformer, rated at 133 MVA.

The following wind facilities are located in the vicinity of the project: Summerhaven Wind Energy Center (“SWEC”), a one hundred and twenty-four (124) megawatt facility bordering the north and east of the PDN Wind Farm.

The facility is designed to operate 24 hours per day, 7 days per week.

### 4 Audit Location

The receptor selection process, monitoring equipment, and details regarding the monitoring locations are provided in this section.

#### 4.1 Receptor Selection

A total of two (2) audit receptors were selected for this I-audit. The receptor selection criteria, including prevailing wind direction and predicted sound levels, used to select the audit receptors are detailed in this section.

##### 4.1.1 Receptor Selection Criteria

Per the requirements of the Compliance Protocol, audit receptors were selected such that they represent the location of the greatest possible predicted noise impacts<sup>1</sup>. The Compliance Protocol also requires data be collected during downwind periods<sup>2</sup>. As such, receptors in locations that are downwind of the nearest turbines are prioritized to assist with timely completion of the I-audit data collection.

##### 4.1.2 Prevailing Wind Direction

Historical wind direction information was provided to Aercoustics by Capital Power and used to support the selection of suitable I-audit receptors. This wind direction information is provided in Figure 1. The most frequently occurring wind direction is taken to be the prevailing wind direction.

From the information in Figure 1, the prevailing downwind direction for the PDN Wind Farm is determined to be 247.5° (west-southwest).

---

<sup>1</sup> “Predicted noise impact” refers to the predicted impacts outlined in the facility acoustic assessment report [5].

<sup>2</sup> A “Downwind” receptor indicates that the direction from receptor to turbine is within +/-45° of the direction of the prevailing winds.




Figure 1: Historical Wind Rose used for Receptor Selection

#### 4.1.3 Receptor Selection Table

Receptors to the PDN Wind Farm's greatest predicted noise impacts are shown in Table 1, sorted in descending order. Selected audit receptors are highlighted in green. Note that the receptors in Table 1 are only the locations that are in a downwind position with respect to the closest turbines. A complete list of receptors is provided in Appendix D.

Table 1: Receptor Selection Table. Locations selected for monitoring are identified in green.

ID	Receptor Type	Height (m)	Distance to Closest Turbine (m)	Nearest Turbine	Predicted Impact (dBA)	Notes
P0472	Participating Receptor	1.5	234	T551	45.9	Participating
P1382	Participating Receptor	4.5	322	T502	42.7	Participating
R0203	Receptor	4.5	646	T525	39.9	Previously measured, high ambient noise*
P1433	Participating Receptor	4.5	421	T511	39.4	Participating
R0487	Receptor	4.5	615	T552	39.3	Selected Receptor
R0241	Receptor	4.5	560	T533	39.2	High ambient noise*
R0488	Receptor	4.5	686	T552	39.2	Redundant to R487
R0413	Receptor	4.5	691	T541	38.5	High ambient noise*
R0303	Receptor	4.5	754	T537	38.5	Declined land access

V2727	Vacant Lot	4.5	626	T558	38.5	Declined land access
R0122	Receptor	4.5	592	T513	38.3	High ambient noise*
R0322	Receptor	1.5	557	T558	38.3	High ambient noise*
R0025	Receptor	1.5	558	SWEC T014	38.3	High ambient noise*
V2820	Vacant Lot	4.5	754	T540	38.2	Selected Receptor

\* Measured or predicted to have significant impacts from ambient or third party noise sources.

Predicted receptor noise impacts were determined using the Acoustic Assessment Report for PDN Wind Farm, prepared by RWDI AIR Inc. and dated November 14, 2014 [5]. Sound levels at the monitoring locations were determined by Aeroustics using the same modelling parameters as the original noise report.

## 4.2 Monitoring Location

The location of the monitoring equipment for each audit receptor is described below. Coordinates for receptor and monitor locations, as well as distances to the nearest or primary<sup>3</sup> turbine are provided in Table 2.

**V2820:** The monitor was erected approximately 78 metres from the audit receptor, towards the nearest turbine. The ground cover between the monitoring location and the nearest turbines was open fields divided by two bush lined fences.

**R487:** The monitor was erected approximately 84 metres from the audit receptor, towards the nearest turbine. The ground cover between the monitoring location and the nearest turbines was open field planted with soybeans. The monitor was located 30 metres from the from a wooded area to the south and 30 metres from an old barn to the east. Note that this location represents a closer monitoring position to the turbines than was used in the Spring 2020 period. During the blade repair process, the monitor was moved away from the nearby barn and closer to the nearest turbines by approximately 35 metres to increase signal-to-noise and data quality.

---

<sup>3</sup> Primary turbine refers to the individual turbine having the highest predicted noise impact at the subject receptor. In certain cases, this may not correspond to the closest turbine.

Table 2: Coordinates and Primary Turbine for each Receptor and Monitor Location

Audit Receptor	Coordinates (UTM x,y, Zone 17T)		Primary Turbine ID	Distance to Primary Turbine	
	<i>Receptor</i>	<i>Monitor</i>		<i>Receptor</i>	<i>Monitor</i>
V2820	584261 mE / 4744686 mN	584195.6 mE / 4744675.2 mN	T540	754 m	679 m
R487*	586087 mE / 4744171 mN	586029.3 mE / 4744235.7 mN	T552	615 m	553 m

\* Monitor location for Aug – November 2020. Spring location was 586059 m E / 4744216 m N

Site plans and photographs of the monitoring equipment are provided in Appendix A. Details regarding the monitoring equipment are provided in Section 5.1.

### 4.3 Ambient Environment

PDN Wind Farm is located in a rural (Class III) area. Ambient noise in rural areas is typically driven by a mixture of flora, fauna, traffic, and nearby industry. Each of these sources and their impacts on the ambient environment are discussed in this section. If the ambient noise is extraneous – such as a short-duration event, or noise concentrated at specific frequencies – then filtering is employed to reduce or remove it (see Section 5.3.2). If the ambient noise is not extraneous, then efforts are made to ensure that the noise is equally represented in both *Total Noise* and *Background* periods (see Section 5.3.3).

In addition to ambient noise sources, self-generated noise from the monitoring equipment is typically present in the measurement data at high wind speeds. This noise is minimized by the usage of a primary and secondary wind screen installed around the microphone. The larger secondary wind screen meets the requirements of Section D2.1.4 of the Compliance Protocol and the insertion loss of the wind screen is tested and accounted for in the analysis. Self-generated noise is assumed to be equally present in *Total Noise* and *Background* periods for a given wind speed.

#### 4.3.1 Flora

Noise from flora was found to be the main driver of the ambient noise during the I-audit at high winds speeds. The noise from flora is generated by the vegetation around the two monitors and is proportional to both ground level and hub height wind speeds.

#### 4.3.2 Fauna

Occasional activity from birds or dogs introduced extraneous noise in a small number of intervals, which were removed from the dataset. Extraneous noise from insects was found to be significant at frequencies above 1600 Hz, and was removed from the assessment via the 1/3<sup>rd</sup> octave spectra (see Section 5.3.2).

#### 4.3.3 Traffic

Noise from traffic was found to be an occasional source of extraneous noise during the I-audit. Roadways near the project include Concession 2 Walpole and Concession 3

Walpole. Intervals influenced by car passbys were removed from the dataset whenever possible (see Section 5.3.2).

#### 4.3.4 Industry

There are a few heavy industrial sites in the Nanticoke area, including the Imperial Oil Refinery and the Stelco Lake Erie Works. Both sites are more than 6 km away from the nearest audit receptor and are not suspected to have had a significant impact on the measurement dataset.

#### 4.3.5 Other Sources

No significant contamination from other sources was found in the measurement dataset.

## 5 Audit Methodology

For the duration of the I-audit, acoustic and weather data are logged simultaneously in one-minute intervals at each monitoring location. Analysis and filtering are conducted per Section D5.2 of the Compliance Protocol with additional filters applied as needed – following the guidance the Compliance Protocol – to remove or reduce extraneous ambient noise (see Section 5.3.2) and ensure representative ambient conditions (see Section 5.3.3).

Intervals that pass the filtering criteria are sorted into integer wind bins<sup>4</sup> depending on the measured wind speed and classified as either *Total Noise* or *Background* depending on the operation of the nearby PDN Wind Farm turbines (see Section 5.3.1). The *Turbine-Only* sound level at each wind bin is then determined by logarithmically subtracting the average *Background* level from the *Total Noise* level in wind bins having sufficient data for assessment. Minimum thresholds for sufficient data are discussed in Section 5.5.1.

### 5.1 Monitoring Equipment

The following acoustic and non-acoustic monitoring equipment was installed at each monitoring location.

- One (1) Type 1 sound level meter with microphone and pre-amplifier, installed at receptor height for V2820 and 1 metre above receptor height for R487 (see Section 5.6.2).
- One (1) primary and one (1) secondary<sup>5</sup> windscreen for the microphone.
- One (1) anemometer installed 10 metres above ground level (“10m-AGL”).

---

<sup>4</sup> An integer wind bin spans 1 m/s, centred on each integer wind speed, open at the low end and closed at the high end.

<sup>5</sup> The 1/3 octave band insertion loss of the secondary windscreen has been tested and has been accounted for in the data analysis.



The monitoring equipment was configured to log one-minute equivalent sound levels ( $L_{eq}$ ) in A-weighted broadband and 1/3<sup>rd</sup> octave band frequencies. The microphone was installed at least 5 metres away from any large reflecting surfaces, as far away as practically possible from trees and other foliage, and in direct line of sight to the nearest PDN Wind Farm turbines.

Table 3 lists the specific make, model, and serial number for the monitoring equipment used at each audit receptor.

Table 3: Monitoring Equipment Details

Audit Receptor	Equipment	Make/Model	Serial Number	Date of Last Calibration
V2820	Sound Level Meter	NI 9234	1B3CE71	Dec 06, 2019
	Microphone	PCB 378B02	121695	Nov 26, 2019
	Pre-amplifier	PCB 426E01	156314	Nov 26, 2019
	Signal Conditioner	PCB 480E09	37185	Aug 24, 2019
	Weather Station	Vaisala WXT520	P4830521	Nov 28, 2018
R487	Sound Level Meter	NI 9234	1A67099	May 14, 2020
	Microphone	PCB 378B02	123029	May 05, 2020
	Pre-amplifier	PCB 426E01	158838	May 05, 2020
	Signal Conditioner	PCB 480E09	33804	May 12, 2020
	Weather Station	Vaisala WXT520	L0910581	July 11, 2019

Each measurement chain was calibrated before, during, and after the measurement period using a type 4231 Brüel & Kjær acoustic calibrator. The monitoring equipment is also verified by laboratory calibration per the requirements in Section D2.3 of the Compliance Protocol; calibration certificates are provided in Appendix B.

## 5.2 Measurement Parameters

The monitoring equipment is configured to run nightly from approximately 9pm to 6am, local time. The measurement parameters acquired and used in the audit are listed in Table 4.

Table 4: Measurement parameters used for the I-audit

Parameter Group	Measurement Parameters	Notes
Acoustic (microphone height)	$L_{Aeq}$	dBA
	$L_{90}$	dBA
	1/3 <sup>rd</sup> Octave Band	dBA (20 Hz–10 kHz)
	Signal Recording	Uncompressed raw files
Weather (10m height)	Wind Speed	m/s
	Wind Direction	0-360°
	Temperature	°C
	Humidity	0-100%
	Precipitation	mm
Turbine (hub height)	Wind Speed	m/s
	Yaw Angle	0-360°
	Power Output	kW
	Rotational Speed	RPM

Turbine operational information was obtained from the facility SCADA system and provided to Aercoustics by Capital Power.

### 5.3 Filtering Criteria

Analyses and filtering of the intervals in the measurement dataset are conducted per the requirements outlined in Section D5.2 and E5.5 of the Compliance Protocol. Intervals are included or excluded from analysis depending on several filtering criteria. Some of these criteria apply to all intervals and some apply only for *Total Noise* or *Background* intervals. Measurement intervals are first passed through the *All Intervals* filters, after which they are sorted into either *Total Noise* or *Background* categories based on the operation of the nearby turbines. Intervals that fail to meet the applicable filtering criteria are excluded from analysis.

#### *All Intervals*

- Have occurred between 10pm – 5am
- Have no precipitation within one hour before or after
- Have an ambient temperature above -20°C
- Have minimal influence from extraneous ambient noise (see Section 5.3.2)

#### *Total Noise Intervals*

- Have all nearby turbines operating (see Section 5.3.1)
- Have primary turbine generating at least 85% of its maximum rated power output
- Have a downwind wind direction (primary turbine to monitor, +/- 45°)

### *Background Intervals*

- Have all nearby turbines parked (see Section 5.3.1)
- Have ambient conditions representative of Total Noise periods (Section 5.3.3)

Measurement intervals that pass the filtering criteria above form the assessment dataset for the I-audit.

#### 5.3.1 Turbines in Study Area

As noted above, several filtering criteria are applied based on the operation of the primary turbine or the turbines in the surrounding area. To verify the operation of these turbines, information from the facility SCADA system is examined.

In order for a measurement interval to be considered for the *Total Noise* or *Background* periods, all the turbines in the study area must be operating or parked, respectively. The minimum number of turbines included in the study area for each receptor are selected based on the guidance of Section D3.5.2 of the Compliance Protocol:

#### **D3.5.2 Acoustic measurements with wind turbines parked**

*“Ambient noise measurements shall be carried out at a point of reception with all turbines in the vicinity of the point of reception parked. The prediction model will be used to determine the number of turbines that require parking in order for the predicted noise contribution of the wind facility to fall to 30 dBA or 10 dB less than the applicable criterion.”*

The PDN Wind Farm turbines in the audit study area for each receptor are listed in Table 5 and conform to the Compliance Protocol requirements listed above. All turbines were confirmed to be operating for Total Noise periods and parked for Background periods.

The turbines confirmed to be operating for Total Noise periods were all those within 3 kilometres of a monitor location. The turbines required to be confirmed as parked for Background periods were those that were predicted to cause the contribution of the wind facility to exceed 30 dBA at a monitor location.

Table 5: Turbines included in the study area for each receptor

Audit Receptor	Turbines verified for Total Noise Measurements	Turbines verified for Background Measurements
V2820	T533, T534, T536, T538, T539, T540, T541, T543, T546, T547, T548, T549, T550, T551, T552, T553	T540, T541, T547, T548, T549, T550, T551, T552
R487	T540, T541, T543, T546, T547, T548, T549, T550, T551, T552, T553, T554	T547, T549, T550, T551, T552, T553

Parked turbines do not rotate or generate power. There is some idling of the blades (~1 rpm or less), but the acoustic impact of the turbines in this condition is negligible at

the receptor. The turbines in the study area were confirmed to be running in their normal operating mode for the duration of the monitoring campaign, see Appendix C for a statement from the operator.

### 5.3.2 Removal of Extraneous Noise

'Extraneous noise' is noise unrelated to the operation of the wind facility that is not part of the typical ambient environment in the area. It is typically noise that is short-duration (i.e. transient) or noise that is limited to specific frequencies. Extraneous noise is considered acoustic contamination and should be removed from the measurement dataset wherever possible. The Compliance Protocol provides the following guidance regarding extraneous noise:

#### **C2.4.7 Extraneous noise sources<sup>6</sup>**

*"Measurements are to be inhibited when the sound level is affected by noise from extraneous sources such as vehicle noise, dogs barking and wind gusts (i.e. other than wind turbine sound)."*

*The same result can also be achieved by digitally recording the sound level time history and later editing out the extraneous events and recalculating the descriptors such as Leq. This should address measurement situations where extraneous sounds were not inhibited.*

#### **D3.5 Acoustic measurements**

*"[...] In addition, if the background sound levels are greater than the applicable exclusion limits then the applicable limits are the background sound levels without extraneous noise sources."*

#### **D5.3 Effects of insects and fauna**

*"The analysis shall identify the influence of any insects, fauna, or other extraneous but constant sources of noise and verify them through sound recordings. Noise from insects can be removed from the 1/3rd octave spectra of each measurement. It has to be shown, however, that the contribution of the wind turbine noise in those frequencies is minimal."*

#### **D6 Assessment of compliance**

*"[...] However, if the background sound levels are greater than the applicable exclusion limits then the applicable limits are now the background sound levels without extraneous noise sources."*

---

<sup>6</sup> It is acknowledged that the measurements in this report follow Part D and Part E of the Compliance Protocol and this guidance is from Part C. Nevertheless, the guidance regarding the removal of extraneous noise in Part C is applicable here as the requirement to remove contamination from the measurement dataset follows good engineering principles for noise measurements.

Extraneous noise can be steady or transient. Steady extraneous noise, such as the noise from crickets or other insects, may be removed via filtering of specific 1/3<sup>rd</sup> octave bands affected by the contamination (see Protocol section D5.3).

Transient extraneous noise, such as the noise from car passes, dogs, or wind gusts, may be removed via a combination of automatic and manual filtering techniques. Automatic filtering of transient extraneous noise is achieved by removing points where the measured  $L_{Aeq}$  is significantly greater than the measured  $L_{90}$  for the same interval. Manual filtering of extraneous noise is conducted via listening tests to identify intervals having audible contamination.

Note: the identification and removal of extraneous noise in the measurement datasets presented in this report is achieved by listening tests, removing 1/3<sup>rd</sup> octave bands above 1600 Hz from the assessment, and an automatic filter that excludes any Total Noise or Background interval if the difference between average and minimum sound level for the interval ( $L_{Aeq}-L_{90}$ ) is greater than 10 dB. The impact of the PDN Wind Farm at 1/3<sup>rd</sup> octave frequency above 1600 Hz is predicted to be less than 30 dBA at the monitor and therefore are considered negligible.

#### 5.3.3 Representative Ambient Conditions

The ambient conditions present in the *Total Noise* and *Background* periods should be similar. Section D3.8.2 of the Compliance Protocol specifically states that weather and wind shear conditions should be similar:

***D3.8.2 Overall equivalent sound level – wind turbines parked***

*“Ambient noise measurements should be performed with the turbines parked and conducted within the same general measurement period and with the same weather and wind shear conditions. Measurements of ambient noise obtained during other periods are not recommended and should only be used with great caution to ensure that they represent the “current” ambient noise.”*

Note: turbine shutdowns were conducted periodically throughout the I-audit to ensure similar weather conditions between Total Noise and Background periods. Further the assessment dataset for R487 includes a downwind direction filter and both datasets include a minimum hub height wind speed filter.

#### 5.4 Adjacent Wind Facilities

The SWEC wind facility is located on the northern and eastern edges of the PDN Wind Farm. The closest SWEC turbines to the monitoring locations are approximately 1.86 km from R487, and 2.65 km from V2820. Based on Aeroustics’ sound model of the PDN Wind Farm, the predicted downwind impacts from the SWEC facility are 28.4 dBA at V2820 and 30.6 dBA at R487. The closest SWEC turbines are crosswind of V2820 and upwind of R487, compared to the nearest turbines of both receptors.

Given that the predicted impact is below 30 dBA at V2820, and marginally above 30 dBA at R487 in an upwind direction, the impacts from the SWEC facility are considered negligible and are not accounted for in the analysis. There are no other wind facilities adjacent to the PDN Wind Farm.

## 5.5 Compliance Criteria

The criteria for an assessment of compliance per the Compliance Protocol are detailed in this section.

### 5.5.1 Sample Size Requirements

This audit follows the requirements of the Revised Assessment Methodology – Immission (“RAM-I”). Analysis parameters for RAM-I are detailed in Section E5.5 of the Compliance Protocol. Relevant sections regarding sample size requirements as they pertain to this I-audit are also copied below:

*E5.5(1): “The objective of the RAM I-Audit is to assess the acoustic immission at the measurement location at wind speeds between 1 and 7 m/s (inclusive). At a minimum, data must be acquired to satisfy the requirements of at least one of the following:*

- a. three (3) of the wind speed bins between 1 and 7 m/s (inclusive), or*
- b. two (2) of the wind speed bins between 1 and 4 m/s (inclusive).”*

*E5.5(5): “The Ministry may accept a reduced number of data points for each wind speed bin with appropriate justification (i.e. 60 data points in place of 120 for turbine operational measurements and 30 data points in place of 60 data points for ambient measurements). The acceptable number of data points will be influenced by the quality of the data (standard deviation).”*

In this study, a wind bin is considered complete if there are at least 60 valid *Total Noise* and 30 valid *Background* intervals.

### 5.5.2 Sound Level Limits

The area surrounding the PDN Wind Farm has been designated as Class III (rural). Exclusion limits for a Class III area are summarized in Table 6 below.

Table 6: MECP Exclusion Limits (Class III)

Wind speed at 10m height (m/s)	Sound Level Exclusion Limit (dBA)
≤ 6	40
7	43

Sections D3.5 and D6 of the Compliance Protocol state that where the measured *Background* sound level exceeds the exclusion limits, the sound level limit for that wind bin is the *Background* sound level without extraneous noise sources. Wind bins where the measured *Background* sound level exceed the exclusion limits are noted in Table 11.

### 5.5.3 Tonality

A tonality assessment of the measurement data has been conducted at the request of the MECP, as outlined in the MECP Letter. The calculation of the mean tonal audibility attributable to the PDN Wind Farm turbines is determined in accordance the IEC 61400-11:2012 standard [6]. Frequencies of interest were determined using the original E-audit reports for the PDN Wind Farm (Table 13 of [7] and [8]). Following the guidance of Section D3.8.3 of the Compliance Protocol, frequencies of any detected tones having a tonal audibility greater than 3 dB in the E-audit test were used in the tonality assessment. One frequency of interest was determined: ~136-186 Hz. Calculations were conducted using narrowband spectra calculated using the measurement intervals from the assessment dataset.

Tonal audibility penalties, if applicable, for each wind bin are calculated according to Annex C of ISO 1996-2:2007 [9] and Section E5.5.2 of the Compliance Protocol. Applicable tonal penalties are determined using the mean tonal audibility. The calculation method for a tonal penalty is summarized in Table 7. Tonal penalties are applied to the turbine-only sound level.

Table 7: Calculation of Applicable Tonal Penalty

Mean Audibility, $\Delta L$	Tonal Adjustment, $K_T$
$\Delta L \leq 4$ dB	0 dB
$4 \text{ dB} < \Delta L \leq 10$ dB	$\Delta L - 4$ dB
$10 \text{ dB} < \Delta L$	6 dB

## 5.6 Deviations

Any deviations from the methods prescribed in the Compliance Protocol are discussed in this section.

### 5.6.1 Measurement Bandwidth

As noted in Table 4, the measurement bandwidth used is 20-10,000 Hz. This is a deviation from the Compliance Protocol section D2.1.1 requirement of a 20-20,000 Hz frequency response. Due to the high attenuation of noise levels at high frequencies, noise at the receptor from the wind facility above 10,000 Hz will be insignificant<sup>7</sup>.

### 5.6.2 Microphone Height – R487 Monitor

Due to an oversight during the monitor installation process, the microphone height for the R487 monitor was installed at 5.5 metres, 1 metre higher than the height of the audit receptor. This change would result in a slightly higher measured facility sound level

---

<sup>7</sup> From Table 2 of ISO 9613-2, acoustic frequencies above 8 kHz experience attenuation from atmospheric absorption of more than 80 dB/km. This combined with the other sources of attenuation will reduce high frequency noise to negligible levels by the time it reaches the receptor.

compared to level at the 4.5 metre receptor height. This deviation is not considered to be significant.

## 6 Audit Results

Measurement results of the I-audit are summarized in the following sections. Sound levels presented here are rounded to the nearest integer, whereas all calculations are conducted using un-rounded values.

### 6.1 Audit Duration

The length of monitoring time at each location is summarized below in Table 8. The period indicated below for R487 represents the monitoring conducted after blade repairs were confirmed complete by the operator.

Table 8: Length of monitoring campaign for each audit receptor

Audit Receptor	Audit Start Date	Audit End Date	Monitoring Duration (weeks)
V2820	May 8, 2020	July 28, 2020	12
R487	July 31, 2020	Nov 6, 2020	14

### 6.2 Weather Conditions

The range of weather parameters measured at each monitor during the I-audit are summarized in Table 9. These values show the range in weather conditions measured in the assessment dataset.

Table 9: Range of weather conditions in assessment dataset

Audit Receptor	Atmospheric Pressure (hPa)	10m-AGL Wind Speed (m/s)	Relative Humidity (%)	Temperature (°C)	Hub-Height Wind Speed (m/s)
V2820	980 – 1001	0.6 – 7.5	50 – 90	7.7 – 25.8	5.0 – 15.7
R487	981 – 998	1.3 – 7.5	57 – 90	-0.1 – 20.0	8.0 – 14.4

Wind roses showing the measured wind directions at each audit location are provided in Figure 2. This data represents the range of wind directions for all measurement data collected during the audit, not just the assessment dataset. Note that wind directions shown on the wind roses indicate the direction the wind is coming from, and the red shaded area represent the downwind angle for each receptor.






Figure 2: Wind Roses for monitors V2820 (left) and R487 (right). Data presented includes all measured data. Wind direction is taken from the yaw angle of the primary turbine and wind speed is taken from the 10m-AGL weather station.

### 6.3 Data Excluded due to Filtering Criteria

The Compliance Protocol requires that assessment data be counted only during downwind and high-power conditions, both of which vary independently with time. As a measure of how often the minimum suitable conditions materialized during the I-audit, the total proportion of measurement time where these two conditions were satisfied is presented in Table 10. This data shows how often during the I-audit the minimum assessment requirements in the Compliance Protocol were met at each audit receptor.

Table 10: Prevalence of Occurrence of Suitable Turbine Conditions

Audit Receptor	Primary Turbine	Prevalence of Downwind	Prevalence of High Output, >85% power	Prevalence of Downwind and High Output
V2820	T540	40%	6%	2%
R487	T487	27%	30%	3%

It is noted that the proportion of measurement data indicated above in Table 10 represents the maximum available data for assessment. Additional filters applied to remove contaminated or otherwise unsuitable measurement data (as discussed in Section 5.3) will further reduce the assessment dataset.

### 6.4 Measured Sound Levels

Valid measurement intervals that pass the filtering criteria are logarithmically averaged and sorted by wind bin into *Total Noise* and *Background* datasets. These average sound levels are presented below in Table 11. Measurement data points from Table 11 are also

plotted in Figure 3 and Figure 4. Sufficient valid measurements were acquired at both monitors to meet the minimum sample size requirements as indicated in Section E5.5(1) of the Protocol.

Table 11: Average measured sound levels at each monitoring Location

Audit Receptor	Period	Measurement Parameter	Wind Bin (m/s)						
			1	2	3	4	5	6	7
V2820	Total Noise	Number of Samples	0	5	8	25	75	104	67
		Average $L_{Aeq}$ [dBA]	-	-	-	40*	41	43	46
		Standard Deviation [dB]	-	-	-	0.9	1.4	1.6	1.6
	Background	Number of Samples	93	217	349	182	63	35	33
		Average $L_{Aeq}$ [dBA]	31	32	33	34	37	42	45
		Standard Deviation [dB]	1.9	1.9	1.6	2.0	2.1	2.3	1.3
R487	Total Noise	Number of Samples	2	126	305	84	24	5	22
		Average $L_{Aeq}$ [dBA]	-	42	43	43	42*	-	44*
		Standard Deviation [dB]	-	1.0	0.9	1.2	1.6	-	1.2
	Background	Number of Samples	3	83	192	75	16	16	11
		Average $L_{Aeq}$ [dBA]	-	38	39	40	38*	38*	41*
		Standard Deviation [dB]	-	2.0	1.3	1.3	2.1	1.6	1.7

- Sample size below reporting requirements in this wind bin, sound levels not reported except as noted by (\*).

\* Below minimum sample size requirements, data presented for information only.




Figure 3: All valid Total Noise and Background intervals measured at V2820 Monitor




Figure 4: All valid Total Noise and Background intervals measured at R487 Monitor.

## 6.5 Sound Level Adjustments

The following sections detail any adjustments made to the sound levels presented in Section 6.4.

### 6.5.1 Tonal Adjustment

Tonal audibility results are presented below in Table 12. Tones with a Tonal Presence less than 20% or a Tonal Audibility less than -3 dB are not reported, per the IEC 61400-11 methodology.

Table 12: Tonality Assessment Table – 136-186 Hz

Audit Receptor	Tonality Parameter	Wind Bin (m/s)						
		1	2	3	4	5	6	7
<b>V2820</b>	Data Points in Wind Bin	0	5	8	25	75	104	67
	Data Points with Tone	0	5	3	1	3	4	1
	Tonal Presence	0%	100%	38%	4%	4%	4%	1%
	Tonal Audibility, $\Delta L$ [dB]	-	-	-	-	-	-	-
	Tonal Adjustment, $K_T$ [dB]	-	-	-	-	-	-	-
<b>R487</b>	Data Points in Wind Bin	2	126	305	84	24	5	22
	Data Points with Tone	0	10	14	5	1	0	4
	Tonal Presence	0%	8%	5%	6%	4%	0%	18%
	Tonal Audibility, $\Delta L$ [dB]	-	-	-	-	-	-	-
	Tonal Adjustment, $K_T$ [dB]	-	-	-	-	-	-	-

From the results in Table 12, no tones were detected that exceeded the threshold for tonal penalties. Further, no tones were detected that exceeded the IEC 61400-11 reporting threshold of -3 dB.

## 6.6 Turbine-Only Sound Levels

The average *Total Noise* and *Background* sound levels by wind bin at each monitoring location are presented in Table 13. Any sound level adjustments used to determine the Turbine-Only sound level at the audit receptor (Point of Reception) are also presented.

Table 13: Calculated Turbine-Only Sound Levels

Audit Receptor	Measurement Period	Wind Bin (m/s)						
		1	2	3	4	5	6	7
<b>V2820</b>	Total Noise (dBA)	-	-	-	40*	41	43	46
	Background (dBA)	31	32	33	34	37	42	45
	Signal to Noise (dBA)	-	-	-	6.6	4.3	1.5	0.5
	Turbine-Only (dBA) [monitor location]	-	-	-	39*	39	38	36
	Turbine-Only (dBA) [Point of Reception]	-	-	-	39*	39	38	36
<b>R487</b>	Total Noise (dBA)	-	42	43	43	42*	42*	44*
	Background (dBA)	-	38	39	40	38*	38*	41*
	Signal to Noise (dBA)	-	4.0	3.3	2.9	3.7	3.6	2.7
	Turbine-Only (dBA) [monitor location]	-	40	40	40	40*	40*	40*
	Turbine-Only (dBA) [Point of Reception]	-	40	40	40	40*	40*	40*

- Sample size below reporting requirements in this wind bin, sound levels not reported except as noted by (\*).

\* Below minimum sample size requirements, data presented for information only.

An assessment compliance of the Turbine-Only sound levels at the Point of Reception is provided in Table 14.

## 7 Discussion

The measurement datasets at both receptors collected sufficient data for assessment without requiring any modification of the filters. For V2820, most of the assessment dataset was collected in the 5 m/s wind bin and above. Conversely, for R487 the assessment dataset was primarily collected in the 2 to 4 m/s wind bins. The difference in wind speed bins collected may be attributed to the different time of year (spring vs. fall), and it may also be attributed to the higher levels of vegetation and trees nearby R487 influencing the wind shear profile in the area.

This increased vegetation is likely be the source of higher ambient sound levels measured at R487 in the 1 to 4 m/s wind bins. The Background periods of the assessment dataset at this receptor were filtered for the same wind shear conditions as the Total Noise periods (see Section 5.3.3), and therefore the wind speed at elevation is high even at low ground level wind speed bins. Ambient sound levels in similar studies were found to be proportional to wind speed at both ground level and elevation [10], and therefore may explain the elevated ambient noise at low wind speed bins for this receptor.

Despite higher ambient sound levels at R487, a signal-to-noise above 3 dB was maintained in most of the assessment wind bins. This is due, in part, to the closer monitoring location and the higher microphone height elevating the PDN Wind Farm sound

level at the monitoring location compared to the receptor location<sup>8</sup>. Note that no adjustments to the sound level based on distance or measurement height were applied to either the R487 or V2820 assessment datasets. Therefore, the calculated turbine-only sound levels at these monitoring locations represent a conservative determination of compliance.

At V2820, the highest signal-to-noise levels are present at the lower wind speed bins (4 and 5 m/s). These wind bins have the lowest impact from ambient noise, and therefore the least amount of associated uncertainty in calculation of the turbine-only sound levels. The influence of ambient noise increases in the higher wind bins, and the reduction in turbine-only sound level in the 7 m/s wind bin is likely due to the increased uncertainty due to low signal-to-noise, rather than any actual decrease in the turbine sound level. The predicted sound level of the V2820 monitor is slightly higher than that of the V2820 receptor, and therefore represents a somewhat conservative determination of turbine-only sound level.

All Total Noise wind bins having sufficient data meet the MECP standard deviation targets of 2/2.5 dB (Section E5.5(8) of the Protocol).

## 8 Assessment of Compliance

This section provides the results of the measurements and calculations as they pertain to the determination of compliance of the facility. Section 5.5 details the criteria used to evaluate compliance.

### 8.1 Assessment Table

Final Turbine-Only sound levels at the audit receptor (Point of Reception) are compared to the exclusion limits and Background sound levels in Table 14. Turbine-Only sound levels at the audit receptor are calculated by taking the Turbine-Only sound level at the monitoring location and applying any applicable adjustments as indicated in Table 13. Compliance assessments are provided only for wind bins meeting the minimum sample size requirements.

---

<sup>8</sup> Per Aeroustics' sound model of the PDN Wind Farm, the predicted sound level is 0.9 dB higher at the monitoring location for R487 compared to the point of reception.

Table 14: Assessment Table

Audited Receptor	Wind speed 10m-AGL [m/s]	1	2	3	4	5	6	7
<b>V2820</b>	Turbine-Only Sound Level (Point of Reception) [dBA]	-	-	-	39*	39	38 <sup>a</sup>	36 <sup>a</sup>
	Background Sound Level [dBA]	31	32	33	34	37	42 <sup>b</sup>	45 <sup>b</sup>
MECP Exclusion Limit [dBA]		40	40	40	40	40	40	43
Compliance? (Y/N)		-	-	-	-	Y	Y	Y
<b>R487</b>	Turbine-Only Sound Level (Point of Reception) [dBA]	-	40	40	40 <sup>a</sup>	40*	-	40*
	Background Sound Level [dBA]	35*	38	39	40	38*	38*	41*
MECP Exclusion Limit [dBA]		40	40	40	40	40	40	43
Compliance? (Y/N)		-	Y	Y	Y	-	-	-

- Sample size below minimum requirements in this wind bin, sound levels not reported except as noted by (\*).

\* Below minimum sample size requirements, data presented for information only.

<sup>a</sup> Signal-to-noise level less than 3 dB. Increased uncertainty in determination of Turbine-Only Sound Impact.

<sup>b</sup> Average measured Background sound level higher than MECP Exclusion Limit

## 8.2 Statement of Compliance

Based on the results presented in Table 14, the Turbine-Only sound levels at the audit receptors for PDN Wind Farm are in compliance with the applicable sound level limits.

## 9 Conclusion

An acoustic immission audit per the requirements of the MECP Compliance Protocol for Wind Turbine Noise was conducted at PDN Wind Farm receptors V2820 and R487. Per the results presented in this report and summarized in Table 14, the noise impacts at both receptors were found to be in compliance with the applicable sound level limits.

## 10 References

- [1] *Renewable Energy Approval #2869-8VDRCV*, Toronto: Ontario Ministry of the Environment, 2012.
- [2] Government of Ontario, *NPC 350 - Compliance protocol for wind turbine noise*, Toronto: Ministry of the Environment and Climate Change, 2017.
- [3] M. Ubovic, "Acoustic Audits for REA #2869-8VDRCV, Port Dover & Nanticoke Wind Farm," Ministry of the Environment, Conservation and Parks, Toronto, 2018.
- [4] A. Denison and P. Ashtiani, "Port Dover and Nanticoke Wind Power Project - REA # 2869-8VDRCV - Additional RAM I-Audit Measurements Interim Update and Location Change Request," Aeroustics Engineering Limited, Mississauga, 2019.
- [5] S. Schajnoha, B. Coulson and G. Redman, "Port Dover and Nanticoke Wind Project Acoustic Assesment Report," RWDI Air Inc., Guelph, 2014.
- [6] "IEC 61400-11:2012 Wind Turbine - Part 11: Acoustic noise measurement techniques," International Electrotechnical Commission, Geneva, 2012.
- [7] R. Jozwiak and P. Ashtiani, "Port Dover & Natnticoke Wind Farm Turbine T538 - IEC 61400-11 measurement," Aeroustics Engineering Limited, Toronto, 2014.
- [8] R. Jozwiak and P. Ashtiani, "Port Dover & Natnticoke Wind Farm Turbine T543 - IEC 61400-11 measurement," Aeroustics Engineering Limited, Toronto, 2014.
- [9] "ISO 1996-2: Acoustics - Description, measurement and assessment of environmental noise - Part 2: Determination of Sound Pressure Levels," International Organization for Standardization, Geneva, 2007.
- [10] D. Halstead and N. Tam, "A study of background noise levels measured during far-field receptor testing of wind turbine facilities," in *8th International Conference on Wind Turbine Noise*, Lisbon, 2019.




---

## **Appendix A**

### Site Details

---



## Legend

- ▲ Turbine Locations
- ★ Monitor Locations
- Receptor Locations



**Project ID:** 14000.07  
**Drawn by:** DAF  
**Reveiwed by:** DH  
**Date:** November 2020  
**Revision:** 1

**Scale:** As Indicated

Port Dover and Nanticoke  
Wind Farm  
Immission Audit Report

## Appendix A.1

0 1 2 km





## Legend

- ▲ Turbine Locations
- ★ Monitor Locations
- ✚ Receptor Locations



**Project ID:** 14000.07  
**Drawn by:** DAF  
**Reveiwed by:** DH  
**Date:** November 2020  
**Revision:** 1

**Scale:** As Indicated

Port Dover and Nanticoke  
Wind Farm  
Immission Audit Report

## Appendix A.2a

Monitor and Receptor  
Location





## Legend

- ▲ Turbine Locations
- ★ Monitor Locations
- ✚ Receptor Locations



**Project ID:** 14000.07  
**Drawn by:** DAF  
**Reveiwed by:** DH  
**Date:** November 2020  
**Revision:** 1

**Scale:** As Indicated

Port Dover and Nanticoke  
Wind Farm  
Immission Audit Report

## Appendix A.2b

Monitor and Receptor  
Location



---

**Project ID:** 14000.07  
**Drawn by:** DAF  
**Reveiwed by:** DH  
**Date:** November 2020  
**Revision:** 1

**Scale:** As Indicated

---

Port Dover and Nanticoke  
Wind Farm  
Immission Audit Report

## Appendix A.3a

Monitor V2820  
to T540





---

**Project ID:** 14000.07  
**Drawn by:** DAF  
**Reveiwed by:** DH  
**Date:** November 2020  
**Revision:** 1

**Scale:** As Indicated

---

Port Dover and Nanticoke  
Wind Farm  
Immission Audit Report

## Appendix A.3b

Monitor R487  
to T552





---

**Project ID:** 14000.07  
**Drawn by:** DAF  
**Reveiwed by:** DH  
**Date:** November 2020  
**Revision:** 1

**Scale:** As Indicated

---

Port Dover and Nanticoke  
Wind Farm  
Immission Audit Report

## Appendix A.4a

Monitor R487  
to Receptor





---

**Project ID:** 14000.07  
**Drawn by:** DAF  
**Reveiwed by:** DH  
**Date:** November 2020  
**Revision:** 1

**Scale:** As Indicated

---

Port Dover and Nanticoke  
Wind Farm  
Immission Audit Report

## Appendix A.4b

Monitor R487  
to Receptor



---

## **Appendix B**

### Calibration Certificates

---

# Compliant Calibration Certificate



<b>Certificate Number:</b>	6401655.1	<b>OE Number:</b>	21921971
<b>Date Printed:</b>	14-MAY-2020	<b>Page:</b>	1 of 14
<b>Customer:</b>	Aercoustics Engineering Ltd (CA) 5335 Lucas Court ONTARIO Mississauga, L4Z 4A9 CANADA		
<b>Manufacturer:</b>	National Instruments	<b>Model:</b>	NI 9234
<b>Serial Number:</b>	1A67099		
<b>Part Number:</b>	195551B-01L	<b>Description:</b>	MODULE ASSY, NI 9234, 4 AI CONFIGURABLE
<b>Calibration Date:</b>	14-MAY-2020	<b>Issued Date:</b>	14-MAY-2020
<b>Procedure Name:</b>	NI 9234	<b>Recommended Calibration Due:</b>	14-MAY-2021
<b>Procedure Version:</b>	3.6.1.0	<b>Verification Results:</b>	As Found: Passed As Left: Passed
<b>Lab Technician:</b>	Pamela Rotan	<b>Calibration Executive Version:</b>	5.1.0.0
		<b>Driver Info:</b>	NI-DAQmx:18.1.0
<b>Temperature:</b>	23.0° C	<b>Humidity:</b>	44.2% RH

The data found in this certificate must be interpreted as:

**As Found** The calibration data of the unit as received by National Instruments, if the unit is functional.

**As Left** The calibration data of the unit when returned from National Instruments.

The As Found and As Left readings are identical for units not adjusted or repaired.

This calibration conforms to ANSI/NCSS Z540.1 requirement.

The TUR (Test Uncertainty Ratio) of this calibration is maintained at a ratio of 4:1 or greater, unless otherwise indicated in the measurements. A TUR determination is not possible for singled sided specification limits and therefore the absence of a value should not be interpreted as a TUR of 4:1 or greater, but rather undetermined. When provided, the expanded measurement uncertainty is calculated according to the Guide to the Expression of Uncertainty in Measurement (GUM) for a confidence level of approximately 95%.

Measured values greater than the Manufacturer's specification limits are marked as 'Failed', measured values within the Manufacturer's specifications are marked as 'Passed'. NI Service Labs do not consider uncertainties when making statements of compliance to a specification.

This certificate applies exclusively to the item identified above and shall not be reproduced except in full, without National Instruments written authorization. Calibration certificates without signatures are not valid.

The Calibration Certificate can be viewed or downloaded online at [www.ni.com/calibration/](http://www.ni.com/calibration/). To request a hard copy, contact NI Customer Service at Tel:(800) 531-5066 or Email [orders@ni.com](mailto:orders@ni.com).

**Ted Talley**  
Technical Manager

National Instruments Calibration Services Austin  
Building A  
11500 N MoPac Expwy  
AUSTIN, TX 78759-3504  
USA  
Tel: (800) 531-5066



**Calibration Notes**

Type	Note
Asset	Verification and adjustment were performed.

**Standards Used**

Manufacturer	Model	Type	Tracking Number	Calibration Due	Notes
Fluke	5720A	Calibrator	9379	27-JUL-2020	
National Instruments	PXI-4461	Function generator	9383	05-MAY-2021	
National Instruments	PXI-4071	Digital multimeter	9433	28-AUG-2020	
National Instruments	PXI-4132	SMU	9845	21-JUN-2020	

The standards used in this calibration are traceable to NIST and/or other National Measurement Institutes (NMI's) that are signatories of the International Committee of Weights and Measures (CIPM) mutual recognition agreement (MRA).

**Calibration Results****As Found****Verify Accuracy**

Lower Range	Upper Range	Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
-5 V	5 V	0	4.00000 V	3.99520 V	3.99991 V	4.00480 V	Passed	
-5 V	5 V	0	0.00000 V	-0.00120 V	-0.00002 V	0.00120 V	Passed	
-5 V	5 V	0	-4.00000 V	-4.00480 V	-3.99990 V	-3.99520 V	Passed	
-5 V	5 V	1	4.00000 V	3.99520 V	3.99987 V	4.00480 V	Passed	
-5 V	5 V	1	0.00000 V	-0.00120 V	-0.00004 V	0.00120 V	Passed	
-5 V	5 V	1	-4.00000 V	-4.00480 V	-3.99993 V	-3.99520 V	Passed	
-5 V	5 V	2	4.00000 V	3.99520 V	3.99968 V	4.00480 V	Passed	
-5 V	5 V	2	0.00000 V	-0.00120 V	-0.00025 V	0.00120 V	Passed	
-5 V	5 V	2	-4.00000 V	-4.00480 V	-4.00016 V	-3.99520 V	Passed	
-5 V	5 V	3	4.00000 V	3.99520 V	3.99993 V	4.00480 V	Passed	
-5 V	5 V	3	0.00000 V	-0.00120 V	-0.00001 V	0.00120 V	Passed	
-5 V	5 V	3	-4.00000 V	-4.00480 V	-3.99991 V	-3.99520 V	Passed	



## As Found

## Verify Gain Matching

Max Gain Difference for Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	10240	10240	4 V	-0.040 dB	-0.000 dB	0.040 dB	Passed	
1	10240	10240	4 V	-0.040 dB	-0.000 dB	0.040 dB	Passed	
2	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	
3	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	

## As Found

## Verify Phase Matching

Max Phase Difference for Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	16384	1000 Hz	-0.085 Degrees	-0.018 Degrees	0.085 Degrees	Passed	
1	51200	16384	1000 Hz	-0.085 Degrees	0.012 Degrees	0.085 Degrees	Passed	
2	51200	16384	1000 Hz	-0.085 Degrees	-0.011 Degrees	0.085 Degrees	Passed	
3	51200	16384	1000 Hz	-0.085 Degrees	0.018 Degrees	0.085 Degrees	Passed	
0	51200	16384	10000 Hz	-0.490 Degrees	-0.181 Degrees	0.490 Degrees	Passed	
1	51200	16384	10000 Hz	-0.490 Degrees	0.115 Degrees	0.490 Degrees	Passed	
2	51200	16384	10000 Hz	-0.490 Degrees	-0.108 Degrees	0.490 Degrees	Passed	
3	51200	16384	10000 Hz	-0.490 Degrees	0.181 Degrees	0.490 Degrees	Passed	

## As Found

## Verify Common Mode Rejection Ratio

Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	16384	1000 Hz	40.000 dB	75.422 dB	100.000 dB	Passed	
1	51200	16384	1000 Hz	40.000 dB	74.017 dB	100.000 dB	Passed	
2	51200	16384	1000 Hz	40.000 dB	64.152 dB	100.000 dB	Passed	
3	51200	16384	1000 Hz	40.000 dB	68.947 dB	100.000 dB	Passed	

## As Found

## Verify IEPE Current

Channel	Rate	DMM Range	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	0.01 A	2.000 mA	2.000 mA	2.091 mA	2.200 mA	Passed	
1	51200	0.01 A	2.000 mA	2.000 mA	2.077 mA	2.200 mA	Passed	
2	51200	0.01 A	2.000 mA	2.000 mA	2.085 mA	2.200 mA	Passed	
3	51200	0.01 A	2.000 mA	2.000 mA	2.081 mA	2.200 mA	Passed	



## As Found

## Verify IEPE Compliance Voltage

Channel	Rate	SMU Voltage Limit	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	24 V	2 mA	19.000 V	20.810 V	24.000 V	Passed	
1	51200	24 V	2 mA	19.000 V	20.812 V	24.000 V	Passed	
2	51200	24 V	2 mA	19.000 V	20.812 V	24.000 V	Passed	
3	51200	24 V	2 mA	19.000 V	20.811 V	24.000 V	Passed	

## As Left

## Verify Accuracy

Lower Range	Upper Range	Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
-5 V	5 V	0	4.00000 V	3.99520 V	4.00001 V	4.00480 V	Passed	
-5 V	5 V	0	0.00000 V	-0.00120 V	-0.00000 V	0.00120 V	Passed	
-5 V	5 V	0	-4.00000 V	-4.00480 V	-3.99994 V	-3.99520 V	Passed	
-5 V	5 V	1	4.00000 V	3.99520 V	3.99999 V	4.00480 V	Passed	
-5 V	5 V	1	0.00000 V	-0.00120 V	-0.00001 V	0.00120 V	Passed	
-5 V	5 V	1	-4.00000 V	-4.00480 V	-3.99997 V	-3.99520 V	Passed	
-5 V	5 V	2	4.00000 V	3.99520 V	3.99977 V	4.00480 V	Passed	
-5 V	5 V	2	0.00000 V	-0.00120 V	-0.00021 V	0.00120 V	Passed	
-5 V	5 V	2	-4.00000 V	-4.00480 V	-4.00016 V	-3.99520 V	Passed	
-5 V	5 V	3	4.00000 V	3.99520 V	3.99999 V	4.00480 V	Passed	
-5 V	5 V	3	0.00000 V	-0.00120 V	0.00000 V	0.00120 V	Passed	
-5 V	5 V	3	-4.00000 V	-4.00480 V	-3.99996 V	-3.99520 V	Passed	

## As Left

## Verify Gain Matching

Max Gain Difference for Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	
1	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	
2	10240	10240	4 V	-0.040 dB	-0.000 dB	0.040 dB	Passed	
3	10240	10240	4 V	-0.040 dB	-0.000 dB	0.040 dB	Passed	

## As Left

## Verify Phase Matching

Max Phase Difference for Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	16384	1000 Hz	-0.085 Degrees	-0.019 Degrees	0.085 Degrees	Passed	
1	51200	16384	1000 Hz	-0.085 Degrees	0.012 Degrees	0.085 Degrees	Passed	
2	51200	16384	1000 Hz	-0.085 Degrees	-0.012 Degrees	0.085 Degrees	Passed	
3	51200	16384	1000 Hz	-0.085 Degrees	0.019 Degrees	0.085 Degrees	Passed	
0	51200	16384	10000 Hz	-0.490 Degrees	-0.181 Degrees	0.490 Degrees	Passed	
1	51200	16384	10000 Hz	-0.490 Degrees	0.115 Degrees	0.490 Degrees	Passed	
2	51200	16384	10000 Hz	-0.490 Degrees	-0.108 Degrees	0.490 Degrees	Passed	
3	51200	16384	10000 Hz	-0.490 Degrees	0.181 Degrees	0.490 Degrees	Passed	

As Left

## Verify Common Mode Rejection Ratio

Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	16384	1000 Hz	40.000 dB	69.463 dB	100.000 dB	Passed	
1	51200	16384	1000 Hz	40.000 dB	73.867 dB	100.000 dB	Passed	
2	51200	16384	1000 Hz	40.000 dB	82.002 dB	100.000 dB	Passed	
3	51200	16384	1000 Hz	40.000 dB	74.067 dB	100.000 dB	Passed	



## As Left

## Verify IEPE Current

Channel	Rate	DMM Range	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	0.01 A	2.000 mA	2.000 mA	2.077 mA	2.200 mA	Passed	
1	51200	0.01 A	2.000 mA	2.000 mA	2.077 mA	2.200 mA	Passed	
2	51200	0.01 A	2.000 mA	2.000 mA	2.077 mA	2.200 mA	Passed	
3	51200	0.01 A	2.000 mA	2.000 mA	2.081 mA	2.200 mA	Passed	

As Left

## Verify IEPE Compliance Voltage

Channel	Rate	SMU Voltage Limit	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	24 V	2 mA	19.000 V	20.809 V	24.000 V	Passed	
1	51200	24 V	2 mA	19.000 V	20.811 V	24.000 V	Passed	
2	51200	24 V	2 mA	19.000 V	20.813 V	24.000 V	Passed	
3	51200	24 V	2 mA	19.000 V	20.811 V	24.000 V	Passed	



# ***CERTIFICATE of CALIBRATION***

Make : PCB Piezotronics

Reference # : 161543

Model : 378B02

Customer : Aeroustics Engineering Ltd  
Mississauga, ON

Descr. : Microphone System 1/2" Free Field

Serial # : 123029

P. Order : 2020.05.04C

Asset # : 00813

Cal. status : Received in spec's, no adjustment made.  
Preamp System with Mic 377B02 s/n 158838

*Navair Technologies certifies that the above listed instrument was calibrated on date noted and was released from this laboratory performing in accordance with the specifications set forth by the manufacturer.*

*Unless otherwise noted in the calibration report a 4:1 accuracy ratio was maintained for this calibration.*

*Our Quality System system complies with the requirements of ISO-9001-2015 and is registered under certificate CA96/269, working standards used for calibration are certified by or traceable to the National Research Council of Canada or the National Institute of Standards and Technology.*

Calibrated : May 05, 2020

By :



Cal. Due : May 05, 2022

Petro Onasko

Temperature : 23 °C ± 2 °C    Relative Humidity : 30% to 70%

Standards used : J-216 J-324 J-333 J-420 J-512

## ***Navair Technologies***

**REPAIR AND CALIBRATION TRACEABLE TO NRC AND NIST**

6375 Dixie Rd. Mississauga, ON, L5T 2E7

Phone : 800-668-7440

Fax: 905 565 8325

<http://www.navair.com>

e-Mail: [service@navair.com](mailto:service@navair.com)

The copyright of this document is the property of Navair Technologies

Any reproduction other than by the requiring written approval



Form: 378B02	Approved by: J.R.	Feb-16	Ver 1.0
--------------	-------------------	--------	---------

Calibration Report for Certificate : 161543

Make		Model	Serial	Asset		
PCB Piezotronics		378B02	123029	00813		
PCB Piezotronics		426E01	041180	00813		
PCB Piezotronics		377B02	158838	00813		

### Sensitivity at 250 Hz


Specs Nom	Unit	Min	Reading	Max		In/Out
50.0 mV/Pa		39.72	52.96	62.94		In
-26.02 dB	re 1 V/Pa	-28.02	-25.52	-24.02		In
0 dB	re 50 mV/Pa	-2	0.50	2		In

Ambient Conditions: Static Pressure 99.7 kPa  
Temperature 23.0°C  
Rel.Humidity 31.0%

### Frequency response

	Lower	Upper
Freq	Pressure	Free Field
Hz	dB	dB
31.5	-0.04	-0.04
63.1	-0.02	-0.01
125.9	-0.00	-0.00
251.3	0.00	0.00
502.5	-0.01	-0.01
1005.1	-0.06	-0.03
1978.7	-0.12	+0.12
3957.5	-0.50	+0.41
7914.9	-2.30	+0.49
12663	-6.17	-0.75
15830	-7.22	-0.69

ref



# ***CERTIFICATE of CALIBRATION***

Make : PCB Piezotronics

Reference # : 161619

Model : 480E09

Customer : Aercoustics Engineering Ltd  
Mississauga, ON

Descr. : Conditioning Amplifier

Serial # : 00033804

P. Order : 2020.05.07C

Asset # : 00763

Cal. status : Received in spec's, no adjustment made.

*Navair Technologies certifies that the above listed instrument was calibrated on date noted and was released from this laboratory performing in accordance with the specifications set forth by the manufacturer.*

*Unless otherwise noted in the calibration report a 4:1 accuracy ratio was maintained for this calibration.*

*Our Quality System system complies with the requirements of ISO-9001-2015 and is registered under certificate CA96/269, working standards used for calibration are certified by or traceable to the National Research Council of Canada or the National Institute of Standards and Technology.*

Calibrated : May 12, 2020

By :



Cal. Due : May 12, 2022

Petro Onasko

Temperature : 23 °C ± 2 °C    Relative Humidity : 30% to 70%

Standards used : J-255 J-367 J-512

## ***Navair Technologies***

**REPAIR AND CALIBRATION TRACEABLE TO NRC AND NIST**

6375 Dixie Rd. Mississauga, ON, L5T 2E7

Phone : 800-668-7440

Fax: 905 565 8325

<http://www.navair.com>

e-Mail: [service@navair.com](mailto:service@navair.com)

The copyright of this document is the property of Navair Technologies

Any reproduction other than in full requires written approval

Form: 480E09	Approved by: J. Raposo	Jun-19	Ver 2.0
--------------	------------------------	--------	---------

Calibration Report for Certificate :

161619

Make	Model	Serial No	Asset	Cal by
PCB Piezotronics	480E09	00033804	00763	P.O.

Test	Setting	Input	Min	Reading	Max	In/Out
------	---------	-------	-----	---------	-----	--------

#### Excitation Voltage

• 1			25 Vdc	26.0 Vdc	29 Vdc	In
-----	--	--	--------	----------	--------	----

#### Constant Current Excitation

• 1			2.0 mA	2.95 mA	3.2 mA	In
-----	--	--	--------	---------	--------	----

#### Voltage Gain Accuracy at 1 kHz

• 1	1.000 V		0.98	1.000	1.02	In
• 10	0.100 V		9.80	10.00	10.20	In
• 100	0.010 V		98.0	99.9	102.0	In





# SOH Wind Engineering LLC

141 Leroy Road • Williston, VT 05495 • USA

Tel 802.316.4368 • Fax 802.735.9106 • www.sohwind.com

## CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

**Certificate number:** 19.US2.06160

**Date of issue:** July 08, 2019

**Type:** Vaisala Weather Transmitter, WXT520

**Serial number:** L0910581

**Manufacturer:** Vaisala, Oyj, PL 26, FIN-00421 Helsinki, Finland

**Client:** Aeroustics Engineering Ltd., 1004 Middlegate RD, Suite 1100, S.Tower, Mississauga, ON L4Y 1M4, Canada

**Anemometer received:** July 11, 2019

**Anemometer calibrated:** July 08, 2019

**Calibrated by:** MEJ

**Procedure:** MEASNET, IEC 61400-12-1:2017 Annex F

**Certificate prepared by:** EJF

**Approved by:** Calibration engineer, EJF

**Calibration equation obtained:**  $v \text{ [m/s]} = 0.99859 \cdot U \text{ [m/s]} + -0.05112$

**Standard uncertainty, slope:** 0.00132

**Standard uncertainty, offset:** -0.27724

**Covariance:** -0.0000175 (m/s)<sup>2</sup>/m/s



**Coefficient of correlation:**  $\rho = 0.999990$

**Absolute maximum deviation:** 0.027 m/s at 4.010 m/s

**Barometric pressure:** 1004.1 hPa

**Relative humidity:** 47.3%

Succession	Velocity pressure, q. [Pa]	Temperature in wind tunnel [°C]	d.p. box [°C]	Wind velocity, v. [m/s]	Anemometer Output, U. [m/s]	Deviation, d. [m/s]	Uncertainty $u_c (k=2)$ [m/s]
2	9.38	25.1	27.2	4.010	4.0400	0.027	0.023
4	14.58	25.1	27.2	5.000	5.0724	-0.014	0.026
6	21.10	25.1	27.2	6.015	6.0767	-0.002	0.030
8	28.66	25.1	27.2	7.011	7.0733	-0.001	0.034
10	37.49	25.1	27.2	8.018	8.0783	0.002	0.038
12	47.61	25.1	27.2	9.036	9.0867	0.013	0.043
13-last	58.65	25.1	27.2	10.029	10.1069	-0.013	0.047
11	71.02	25.1	27.2	11.036	11.1133	-0.010	0.051
9	84.53	25.1	27.2	12.041	12.1300	-0.021	0.056
7	99.09	25.1	27.2	13.037	13.1133	-0.007	0.060
5	114.81	25.1	27.2	14.033	14.1267	-0.023	0.064
3	131.98	25.1	27.2	15.045	15.0967	0.021	0.069
1-first	149.54	25.0	27.2	16.013	16.0600	0.026	0.073



AC-1746



## EQUIPMENT USED

Serial Number	Description
Njord2	Wind tunnel, blockage factor = 1.0035
I3924	Control cup anemometer
-	Mounting tube, D = 19 mm
TT003	Summit Electronics, 1XPT100, 0-10V Output, wind tunnel temp.
TP001	PR Electronics 5102, 0-10V Output, differential pressure box temp.
DP008	Setra Model 239, 0-1inWC, differential pressure transducer
HY002	Dwyer RHP-2D20, 0-10V Output, humidity transmitter
BP003	Setra M278, 0-5VDC Output, barometer
PL3	Pitot tube
XB001	Computer Board. 16 bit A/D data acquisition board
Njord2-PC	PC dedicated to data acquisition

The accuracies of all measurements were traceable to the SI through NIST or CIPM recognized NMI's.



*Photo of the wind tunnel setup. The cross-sectional area is 2.5m x 2.5m.*

## UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ( $k=2$ ) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.12.01.004 for further details.

## COMMENTS

This sensor was positioned at the 0° orientation during calibration.

**Certificate number:** 19.US2.06160

All calibrations are done in the "As Left" condition unless otherwise noted.

This certificate must not be reproduced, except in full, without the approval of SOH Wind Engineering LLC





# SOH Wind Engineering LLC

141 Leroy Road · Williston, VT 05495 · USA

Tel 802.316.4368 · Fax 802.735.9106 · www.sohwind.com

## CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

**Certificate number:** 19.US2.06159

**Date of issue:** July 08, 2019

**Type:** Vaisala Weather Transmitter, WXT520

**Serial number:** L0910581

**Manufacturer:** Vaisala, Oyj, PL 26, FIN-00421 Helsinki, Finland

**Client:** Aeroustics Engineering Ltd., 1004 Middlegate RD, Suite 1100, S.Tower, Mississauga, ON L4Y 1M4, Canada

**Anemometer received:** July 11, 2019

**Anemometer calibrated:** July 08, 2019

**Calibrated by:** MEJ

**Procedure:** MEASNET, IEC 61400-12-1:2017 Annex F

**Certificate prepared by:** EJF

**Approved by:** Calibration engineer, EJF

**Calibration equation obtained:**  $v \text{ [m/s]} = 1.01811 \cdot U \text{ [m/s]} + 0.04684$

**Standard uncertainty, slope:** 0.00323

**Standard uncertainty, offset:** 0.73496

**Covariance:** -0.0001059 (m/s)<sup>2</sup>/m/s



**Coefficient of correlation:**  $\rho = 0.999943$

**Absolute maximum deviation:** -0.083 m/s at 16.023 m/s

**Barometric pressure:** 1004.3 hPa

**Relative humidity:** 47.9%

Succession	Velocity pressure, q. [Pa]	Temperature in wind tunnel [°C]	d.p. box [°C]	Wind velocity, v. [m/s]	Anemometer Output, U. [m/s]	Deviation, d. [m/s]	Uncertainty u <sub>c</sub> (k=2) [m/s]
2	9.36	24.9	27.4	4.004	3.9267	-0.041	0.023
4	14.63	25.0	27.4	5.006	4.8897	-0.019	0.026
6	21.13	25.0	27.4	6.018	5.8933	-0.029	0.030
8	28.67	25.0	27.3	7.009	6.8400	-0.002	0.034
10	37.68	25.0	27.3	8.035	7.8100	0.037	0.039
12	47.58	25.0	27.3	9.030	8.7800	0.045	0.043
13-last	58.71	25.0	27.3	10.031	9.7724	0.035	0.047
11	71.09	25.0	27.3	11.038	10.7900	0.006	0.051
9	84.47	25.0	27.3	12.032	11.7733	-0.001	0.056
7	99.40	25.0	27.3	13.053	12.7633	0.011	0.060
5	115.31	24.9	27.4	14.058	13.6900	0.074	0.064
3	131.95	24.9	27.4	15.039	14.7567	-0.032	0.069
1-first	149.80	24.8	27.5	16.023	15.7733	-0.083	0.073




AC-1746



## EQUIPMENT USED

Serial Number	Description
Njord2	Wind tunnel, blockage factor = 1.0035
13924	Control cup anemometer
-	Mounting tube, D = 19 mm
TT003	Summit Electronics, 1XPT100, 0-10V Output, wind tunnel temp.
TP001	PR Electronics 5102, 0-10V Output, differential pressure box temp.
DP008	Setra Model 239, 0-1inWC, differential pressure transducer
HY002	Dwyer RHP-2D20, 0-10V Output, humidity transmitter
BP003	Setra M278, 0-5VDC Output, barometer
PL3	Pitot tube
XB001	Computer Board. 16 bit A/D data acquisition board
Njord2-PC	PC dedicated to data acquisition

The accuracies of all measurements were traceable to the SI through NIST or CIPM recognized NMI's.



*Photo of the wind tunnel setup. The cross-sectional area is 2.5m x 2.5m.*

## UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ( $k=2$ ) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.12.01.004 for further details.

## COMMENTS

This sensor was positioned at the 90° orientation during calibration.

**Certificate number:** 19.US2.06159

All calibrations are done in the "As Left" condition unless otherwise noted.

This certificate must not be reproduced, except in full, without the approval of SOH Wind Engineering LLC



# Compliant Calibration Certificate



<b>Certificate Number:</b>	6241566.1	<b>OE Number:</b>	21815539
<b>Date Printed:</b>	06-DEC-2019	<b>Page:</b>	1 of 14
<b>Customer:</b>	Aercooustics Engineering LTD (CA) 1004 Middlegate Road Suite 1100 ONTARIO MISSISSAUGA, L4Y 0G1 CANADA		
<b>Manufacturer:</b>	National Instruments	<b>Model:</b>	NI 9234
<b>Serial Number:</b>	1B3CE71		
<b>Part Number:</b>	195551C-01L	<b>Description:</b>	MODULE ASSY, NI 9234, 4 AI CONFIGURABLE
<b>Calibration Date:</b>	06-DEC-2019	<b>Issued Date:</b>	06-DEC-2019
<b>Procedure Name:</b>	NI 9234	<b>Recommended Calibration Due:</b>	06-DEC-2020
<b>Procedure Version:</b>	3.6.1.0	<b>Verification Results:</b>	As Found: Passed As Left: Passed
<b>Lab Technician:</b>	Carlos Perez	<b>Calibration Executive Version:</b>	5.0.2.0
		<b>Driver Info:</b>	NI-DAQmx:19.0.0
<b>Temperature:</b>	23.0° C	<b>Humidity:</b>	40.7% RH

The data found in this certificate must be interpreted as:

**As Found** The calibration data of the unit as received by National Instruments, if the unit is functional.

**As Left** The calibration data of the unit when returned from National Instruments.

The As Found and As Left readings are identical for units not adjusted or repaired.

This calibration conforms to ANSI/NCSL Z540.1 requirement.

The TUR (Test Uncertainty Ratio) of this calibration is maintained at a ratio of 4:1 or greater, unless otherwise indicated in the measurements. A TUR determination is not possible for singled sided specification limits and therefore the absence of a value should not be interpreted as a TUR of 4:1 or greater, but rather undetermined. When provided, the expanded measurement uncertainty is calculated according to the Guide to the Expression of Uncertainty in Measurement (GUM) for a confidence level of approximately 95%.

Measured values greater than the Manufacturer's specification limits are marked as 'Failed', measured values within the Manufacturer's specifications are marked as 'Passed'. NI Service Labs do not consider uncertainties when making statements of compliance to a specification.

This certificate applies exclusively to the item identified above and shall not be reproduced except in full, without National Instruments written authorization. Calibration certificates without signatures are not valid.

The Calibration Certificate can be viewed or downloaded online at [www.ni.com/calibration/](http://www.ni.com/calibration/). To request a hard copy, contact NI Customer Service at Tel:(800) 531-5066 or Email [orders@ni.com](mailto:orders@ni.com).

**Ted Talley**  
Technical Manager

National Instruments Calibration Services Austin  
Building A  
11500 N MoPac Expwy  
AUSTIN, TX 78759-3504  
USA  
Tel: (800) 531-5066





**Calibration Notes**

Type	Note
Asset	Verification and adjustment were performed.

**Standards Used**

Manufacturer	Model	Type	Tracking Number	Calibration Due	Notes
FLUKE	5700A	Calibrator	3020	10-DEC-2019	
Agilent	33250A	Function generator	2472	27-AUG-2020	
National Instruments	PXI-4071	Digital multimeter	9433	28-AUG-2020	
National Instruments	PXI-4132	SMU	9170	06-MAY-2020	

The standards used in this calibration are traceable to NIST and/or other National Measurement Institutes (NMI's) that are signatories of the International Committee of Weights and Measures (CIPM) mutual recognition agreement (MRA).

**Calibration Results****As Found****Verify Accuracy**

Lower Range	Upper Range	Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
-5 V	5 V	0	4.00000 V	3.99520 V	3.99987 V	4.00480 V	Passed	
-5 V	5 V	0	0.00000 V	-0.00120 V	-0.00023 V	0.00120 V	Passed	
-5 V	5 V	0	-4.00000 V	-4.00480 V	-4.00034 V	-3.99520 V	Passed	
-5 V	5 V	1	4.00000 V	3.99520 V	4.00001 V	4.00480 V	Passed	
-5 V	5 V	1	0.00000 V	-0.00120 V	-0.00007 V	0.00120 V	Passed	
-5 V	5 V	1	-4.00000 V	-4.00480 V	-4.00016 V	-3.99520 V	Passed	
-5 V	5 V	2	4.00000 V	3.99520 V	4.00027 V	4.00480 V	Passed	
-5 V	5 V	2	0.00000 V	-0.00120 V	0.00019 V	0.00120 V	Passed	
-5 V	5 V	2	-4.00000 V	-4.00480 V	-3.99991 V	-3.99520 V	Passed	
-5 V	5 V	3	4.00000 V	3.99520 V	4.00010 V	4.00480 V	Passed	
-5 V	5 V	3	0.00000 V	-0.00120 V	0.00006 V	0.00120 V	Passed	
-5 V	5 V	3	-4.00000 V	-4.00480 V	-3.99997 V	-3.99520 V	Passed	

## As Found

## Verify Gain Matching

Max Gain Difference for Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	
1	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	
2	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	
3	10240	10240	4 V	-0.040 dB	-0.000 dB	0.040 dB	Passed	

## As Found

## Verify Phase Matching

Max Phase Difference for Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	16384	1000 Hz	-0.085 Degrees	-0.005 Degrees	0.085 Degrees	Passed	
1	51200	16384	1000 Hz	-0.085 Degrees	0.003 Degrees	0.085 Degrees	Passed	
2	51200	16384	1000 Hz	-0.085 Degrees	0.005 Degrees	0.085 Degrees	Passed	
3	51200	16384	1000 Hz	-0.085 Degrees	0.005 Degrees	0.085 Degrees	Passed	
0	51200	16384	10000 Hz	-0.490 Degrees	-0.045 Degrees	0.490 Degrees	Passed	
1	51200	16384	10000 Hz	-0.490 Degrees	0.031 Degrees	0.490 Degrees	Passed	
2	51200	16384	10000 Hz	-0.490 Degrees	0.045 Degrees	0.490 Degrees	Passed	
3	51200	16384	10000 Hz	-0.490 Degrees	0.039 Degrees	0.490 Degrees	Passed	



## As Found

## Verify Common Mode Rejection Ratio

Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	16384	1000 Hz	40.000 dB	74.938 dB	100.000 dB	Passed	
1	51200	16384	1000 Hz	40.000 dB	73.541 dB	100.000 dB	Passed	
2	51200	16384	1000 Hz	40.000 dB	73.747 dB	100.000 dB	Passed	
3	51200	16384	1000 Hz	40.000 dB	73.868 dB	100.000 dB	Passed	

## As Found

## Verify IEPE Current

Channel	Rate	DMM Range	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	0.01 A	2.000 mA	2.000 mA	2.080 mA	2.200 mA	Passed	
1	51200	0.01 A	2.000 mA	2.000 mA	2.076 mA	2.200 mA	Passed	
2	51200	0.01 A	2.000 mA	2.000 mA	2.078 mA	2.200 mA	Passed	
3	51200	0.01 A	2.000 mA	2.000 mA	2.077 mA	2.200 mA	Passed	

## As Found

## Verify IEPE Compliance Voltage

Channel	Rate	SMU Voltage Limit	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	24 V	2 mA	19.000 V	20.832 V	24.000 V	Passed	
1	51200	24 V	2 mA	19.000 V	20.830 V	24.000 V	Passed	
2	51200	24 V	2 mA	19.000 V	20.830 V	24.000 V	Passed	
3	51200	24 V	2 mA	19.000 V	20.833 V	24.000 V	Passed	

## As Left

## Verify Accuracy

Lower Range	Upper Range	Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
-5 V	5 V	0	4.00000 V	3.99520 V	4.00001 V	4.00480 V	Passed	
-5 V	5 V	0	0.00000 V	-0.00120 V	0.00001 V	0.00120 V	Passed	
-5 V	5 V	0	-4.00000 V	-4.00480 V	-4.00000 V	-3.99520 V	Passed	
-5 V	5 V	1	4.00000 V	3.99520 V	4.00000 V	4.00480 V	Passed	
-5 V	5 V	1	0.00000 V	-0.00120 V	-0.00001 V	0.00120 V	Passed	
-5 V	5 V	1	-4.00000 V	-4.00480 V	-3.99999 V	-3.99520 V	Passed	
-5 V	5 V	2	4.00000 V	3.99520 V	4.00000 V	4.00480 V	Passed	
-5 V	5 V	2	0.00000 V	-0.00120 V	-0.00000 V	0.00120 V	Passed	
-5 V	5 V	2	-4.00000 V	-4.00480 V	-3.99999 V	-3.99520 V	Passed	
-5 V	5 V	3	4.00000 V	3.99520 V	4.00000 V	4.00480 V	Passed	
-5 V	5 V	3	0.00000 V	-0.00120 V	0.00000 V	0.00120 V	Passed	
-5 V	5 V	3	-4.00000 V	-4.00480 V	-3.99998 V	-3.99520 V	Passed	



## As Left

## Verify Gain Matching

Max Gain Difference for Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	
1	10240	10240	4 V	-0.040 dB	-0.000 dB	0.040 dB	Passed	
2	10240	10240	4 V	-0.040 dB	0.000 dB	0.040 dB	Passed	
3	10240	10240	4 V	-0.040 dB	-0.000 dB	0.040 dB	Passed	

## As Left

## Verify Phase Matching

Max Phase Difference for Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	16384	1000 Hz	-0.085 Degrees	-0.005 Degrees	0.085 Degrees	Passed	
1	51200	16384	1000 Hz	-0.085 Degrees	0.003 Degrees	0.085 Degrees	Passed	
2	51200	16384	1000 Hz	-0.085 Degrees	0.005 Degrees	0.085 Degrees	Passed	
3	51200	16384	1000 Hz	-0.085 Degrees	0.005 Degrees	0.085 Degrees	Passed	
0	51200	16384	10000 Hz	-0.490 Degrees	-0.045 Degrees	0.490 Degrees	Passed	
1	51200	16384	10000 Hz	-0.490 Degrees	0.031 Degrees	0.490 Degrees	Passed	
2	51200	16384	10000 Hz	-0.490 Degrees	0.045 Degrees	0.490 Degrees	Passed	
3	51200	16384	10000 Hz	-0.490 Degrees	0.039 Degrees	0.490 Degrees	Passed	

As Left

## Verify Common Mode Rejection Ratio

Channel	Rate	Samples per Channel	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	16384	1000 Hz	40.000 dB	74.967 dB	100.000 dB	Passed	
1	51200	16384	1000 Hz	40.000 dB	72.726 dB	100.000 dB	Passed	
2	51200	16384	1000 Hz	40.000 dB	73.948 dB	100.000 dB	Passed	
3	51200	16384	1000 Hz	40.000 dB	73.851 dB	100.000 dB	Passed	

## As Left

## Verify IEPE Current

Channel	Rate	DMM Range	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	0.01 A	2.000 mA	2.000 mA	2.079 mA	2.200 mA	Passed	
1	51200	0.01 A	2.000 mA	2.000 mA	2.077 mA	2.200 mA	Passed	
2	51200	0.01 A	2.000 mA	2.000 mA	2.078 mA	2.200 mA	Passed	
3	51200	0.01 A	2.000 mA	2.000 mA	2.077 mA	2.200 mA	Passed	



## As Left

## Verify IEPE Compliance Voltage

Channel	Rate	SMU Voltage Limit	Test Value	Low Limit	Reading	High Limit	Status	Notes
0	51200	24 V	2 mA	19.000 V	20.832 V	24.000 V	Passed	
1	51200	24 V	2 mA	19.000 V	20.830 V	24.000 V	Passed	
2	51200	24 V	2 mA	19.000 V	20.834 V	24.000 V	Passed	
3	51200	24 V	2 mA	19.000 V	20.833 V	24.000 V	Passed	

# *CERTIFICATE of CALIBRATION*

Make : PCB Piezotronics

Reference # : 159677

Model : 378B02

Customer : Aeroustics Engineering Ltd  
Mississauga, ON

Descr. : Microphone System 1/2" Free Field

Serial # : 121695

P. Order : 2019.11.19C

Asset # : 00471

Cal. status : Received in spec's, no adjustment made.  
Preamp System with Mic 377B02 s/n 156314

*Navair Technologies certifies that the above listed instrument was calibrated on date noted and was released from this laboratory performing in accordance with the specifications set forth by the manufacturer.*

*Unless otherwise noted in the calibration report a 4:1 accuracy ratio was maintained for this calibration.*

*Our Quality System complies with the requirements of ISO-9001-2015 and is registered under certificate CA96/269, working standards used for calibration are certified by or traceable to the National Research Council of Canada or the National Institute of Standards and Technology.*

Calibrated : Nov 26, 2019

By : 

Cal. Due : Nov 26, 2021

Petro Onasko

Temperature : 23 °C ± 2 °C Relative Humidity : 30% to 70%

Standards used : J-216 J-324 J-333 J-420 J-512

## *Navair Technologies*

REPAIR AND CALIBRATION TRACEABLE TO NRC AND NIST

6375 Dixie Rd. Mississauga, ON, L5T 2E7

Phone : 800-668-7440

Fax: 905 565 8325

[http:// www.navair.com](http://www.navair.com)

e-Mail: [service@navair.com](mailto:service@navair.com)

The copyright of this document is the property of Navair Technologies

Any reproduction other than in full requires written approval



Form: 378B02	Approved by: JR	Feb-16	Ver 1.0
--------------	-----------------	--------	---------

Calibration Report for Certificate : 159677

Make		Model	Serial	Asset		
PCB Piezotronics		378B02	121695	00471		
PCB Piezotronics		426E01	039843	00471		
PCB Piezotronics		377B02	156314	00471		

## Sensitivity at 250 Hz


Specs Nom	Unit	Min	Reading	Max	In/Out
50	mV/Pa	39.72	50.10	62.94	In
-26.02	dB re 1V/Pa	-28.02	-26.00	-24.02	In
0	dB re 50mV/Pa	-2	0.02	2	In

Ambient Conditions: Static Pressure 99.0 kPa  
Temperature 23.2°C  
Rel.Humidity 33.0%

## Frequency response

	Lower	Upper
Freq	Pressure	Free Field
Hz	dB	dB
31.5	-0.04	-0.04
63.1	-0.02	-0.02
125.9	0.00	0.00
251.3	0.00	0.00
502.5	-0.02	-0.01
1005.1	-0.07	-0.05
1978.7	-0.18	0.06
3957.5	-0.66	0.25
7914.9	-2.38	0.42
12663	-5.61	-0.18
15830	-6.48	0.04

ref



## ~ Calibration Certificate ~

Model Number: 480E09

Customer: \_\_\_\_\_

Serial Number: 37185

Description: Signal Conditioner

P.O.: \_\_\_\_\_

Manufacturer: PCB

Method: Comparison Method (AT103-3)

### Calibration Data

Temperature: 73 °F ( 23 °C)

Humidity: 56%

Channel	Volts	Current (mA)	Gain X1	Gain X10	Gain X100
1	27.1	2.98	1.001	10.020	100.097

### Condition of Unit

As Found: n/a

As Left: New unit, in tolerance

### Notes

1. Calibration is N.I.S.T. traceable through PCB control number QC-726.
2. This certificate shall not be reproduced, except in full, without written approval from PCB Piezotronics, Inc.
3. Calibration is performed in compliance with ISO 10012-1, ANSI/NCSL Z540.3 and ISO 17025.
4. Measurement uncertainty (95% confidence level with a coverage factor of 2) for the sensitivity reading is +/- 0.2 %
5. See Manufacturer's Specification Sheet for a detailed listing of performance specifications.

Technician: Darius Story DS

Date: 08/24/19

Due Date: \_\_\_\_\_



**PCB PIEZOTRONICS** INC.

Headquarters: 3425 Walden Avenue, Depew, NY 14043

Calibration Performed at: 10869 Highway 903, Halifax, NC 27839

TEL: 888-684-0013

FAX: 716-685-3886

[www.pcb.com](http://www.pcb.com)



## TEST REPORT

**Product family** WXT530 series  
**Product type** WXT536  
**Order code** 6B1B2A4B1B1B  
**Serial number** P4830521  
**Manufacturer** Vaisala Oyj, Finland  
**Test date** 28 November 2018

This test report certifies that the product was thoroughly tested and inspected, and found to meet its published test limits when it was shipped from Vaisala.

### Test results

Test	Result	Lower limit	Upper limit	Unit
Rain response	401	345	575	mV
Zero wind speed	0	0	0.4	m/s
Pressure difference	-0.22	-1	1	hPa
Temperature difference	0.06	-2	2	°C
Humidity difference	-0.77	-10	10	%RH
Heating current	0.75	0.6	0.8	A
Current (service port)	1.07	0.5	2	mA
Communication (service port)	pass	PASS	PASS	-
Current (main port)	0.73	0.5	2	mA
Communication (main port)	pass	PASS	PASS	-

Ambient conditions / Humidity 15.39 ±5 %RH, Temperature 22.22 ±1 °C, Pressure 1028.01 ±1 hPa.

Signature

Technician

This report shall not be reproduced except in full, without the written approval of Vaisala. DOC233154-A.doc

## CALIBRATION SHEET

**Instrument** WXTPTU  
**Serial number** P4350033  
**Manufacturer** Vaisala Oyj, Finland  
**Test date** 31 October 2018

This test report certifies that the instrument was thoroughly tested and inspected, and found to meet its published test limits when it was shipped from Vaisala.

### Calibration results

Test phase of calibration process	Reference value	Observed value	Difference*	Uncertainty**
Pressure	1076.6	1076.5	-0.1	± 0.4 hPa
Pressure	900.4	900.4	0	± 0.4 hPa
Pressure	798	798	0	± 0.4 hPa
Pressure	599.3	599.3	0	± 0.4 hPa
Temperature	59.7	59.7	0	± 0.2 °C
Temperature	-5.7	-5.7	0	± 0.2 °C
Temperature	-32.5	-32.5	0	± 0.2 °C
Temperature	24.8	24.8	0	± 0.2 °C
Temperature	-51.9	-51.9	0	± 0.2 °C
Relative humidity	29.5	29.5	0	± 2 %RH
Relative humidity	57.7	57.7	0	± 2 %RH
Relative humidity	91.4	91.4	0	± 3 %RH

\*The test points for error values are polynomial fitting curve fitting points.

\*\*The calibration uncertainty given at 95 % confidence level, k = 2

### Traceability

The working standards for pressure and temperature are calibrated at Vaisala Measurement Standards Laboratory (MSL) by using MSL working standards traceable to National Institute of Standards and Technology (NIST, USA). The relative humidity values are calculated from measured temperature and dew-point temperature values. The dew-point working standards are traceable to the Finnish National Humidity Laboratory (MIKES).

Signature

Technician

*This report shall not be reproduced except in full, without the written approval of Vaisala.*

Doc218938-A

---

## **Appendix C**

### Statement from the Operator

---

November 27, 2020

To: Whom it may concern

**RE: Port Dover and Nanticoke Wind – Acoustic Audits  
2020 Acoustic Measurement Campaign  
Renewable Energy Approval Number 2869-8VDRCV**

This letter is to confirm that all the turbines tested at the Port Dover and Nanticoke Wind farm during the spring and fall 2020 acoustic measurement campaign conducted by Aercoustics Engineering Ltd were operating as normal for the duration of the campaign. In addition, for the ambient measurements taken, the turbines were stopped.

If you have any questions, please contact me at (780) 392-5376.

Yours truly,



Jordan Heavenor  
Senior Manager, Renewables - Canada





---

## **Appendix D**

### Supplemental Information

---

Receptor ID	Receptor Type	Height	Distance from Receptor to Source (m)	Nearest Turbine	Predicted Impact (Assessment)	Wind Direction	Added notes
P0472	PDN Participating Receptor	1.5	234	PDNWP T551	45.9	DW	Participating
P0442	PDN Participating Receptor	4.5	322	PDNWP T547	44.6	CW	Participating
P1382	PDN Participating Receptor	4.5	322	PDNWP T502	42.7	DW	Participating
P0431	PDN Participating Receptor	4.5	554	PDNWP T548	41.7	CW	Participating
P0204	PDN Participating Receptor	4.5	611	PDNWP T524	40.6	CW	Participating
P0443	PDN Participating Receptor	4.5	515	PDNWP T546	40.4	CW	Participating
P0196	PDN Participating Receptor	4.5	592	PDNWP T524	40.3	CW	Participating
P1402	PDN Participating Receptor	4.5	563	PDNWP T507	40.2	CW	Participating
P0228	PDN Participating Receptor	4.5	587	PDNWP T535	40.2	CW	Participating
P0459	PDN Participating Receptor	4.5	560	PDNWP T546	40.2	CW	Participating
R0193	Residence	4.5	564	PDNWP T523	40.0	CW	Poor wind direction
R0159	Residence	4.5	586	PDNWP T521	40.0	UW	Poor wind direction
V2824	Vacant Lot	4.5	573	PDNWP T546	40.0	CW	Poor wind direction
V2823	Vacant Lot	4.5	617	PDNWP T546	40.0	CW	Poor wind direction
R1165	Residence	4.5	667	PDNWP TR101	39.9	CW	Poor wind direction
R0203	Residence	4.5	646	PDNWP T525	39.9	DW	Previously measured, high ambient noise
R0211	Residence	1.5	631	PDNWP T524	39.9	CW	Poor wind direction
R0214	Residence	1.5	650	PDNWP T524	39.9	CW	Poor wind direction

Receptor ID	Receptor Type	Height	Distance from Receptor to Source (m)	Nearest Turbine	Predicted Impact (Assessment)	Wind Direction	Added notes
R0088	Residence	4.5	391	PDNWP TR101	39.8	CW	Poor wind direction
R0191	Residence	4.5	660	PDNWP T524	39.8	CW	Poor wind direction
R0126	SWEC Participating Receptor	4.5	581	SWEC T061	39.8	CW	Poor wind direction, nearest turbine not PDN
R0218	Residence	4.5	564	PDNWP T529	39.8	CW	Poor wind direction
R1295	Residence	1.5	573	PDNWP T409	39.8	UW	Poor wind direction
R1394	Residence	4.5	616	PDNWP T506	39.7	CW	Poor wind direction
R3312	Residence	4.5	559	PDNWP T524	39.7	UW	Poor wind direction
R0217	Residence	4.5	582	PDNWP T529	39.7	CW	Poor wind direction
R0463	Residence	4.5	638	PDNWP T546	39.7	CW	Poor wind direction
R0003	Residence	4.5	601	SWEC T020	39.6	CW	Poor wind direction, nearest turbine not PDN
R0197	Residence	4.5	593	PDNWP T523	39.6	CW	Poor wind direction
R0219	Residence	4.5	661	PDNWP T533	39.6	CW	Poor wind direction
V2617	Vacant Lot	4.5	588	PDNWP T506	39.6	CW	Poor wind direction
V2683	Vacant Lot	4.5	548	PDNWP T517	39.6	CW	Poor wind direction
R0444	Residence	4.5	551	SWEC T026	39.5	CW	Poor wind direction, nearest turbine not PDN
P1405	PDN Participating Receptor	4.5	500	PDNWP T507	39.5	CW	Participating
V2615	Vacant Lot	4.5	412	PDNWP TR101	39.5	UW	Poor wind direction
P0238	PDN Participating Receptor	4.5	627	PDNWP T535	39.5	CW	Participating
V2825	Vacant Lot	4.5	708	PDNWP T546	39.5	CW	Poor wind direction

Receptor ID	Receptor Type	Height	Distance from Receptor to Source (m)	Nearest Turbine	Predicted Impact (Assessment)	Wind Direction	Added notes
R0438	Residence	1.5	564	PDNWP T546	39.5	CW	Poor wind direction
P1433	PDN Participating Receptor	4.5	421	PDNWP T511	39.4	DW	Participating
V2822	Vacant Lot	4.5	764	PDNWP T548	39.4	CW	Poor wind direction
R0186	Residence	4.5	683	PDNWP T524	39.4	CW	Poor wind direction
R1385	Residence	4.5	562	PDNWP T505	39.4	CW	Poor wind direction
R1272	Residence	4.5	566	PDNWP T401	39.4	CW	Poor wind direction
R0487	Residence	4.5	615	PDNWP T552	39.3	DW	Selected Receptor
R0099	Residence	4.5	812	SWEC T059	39.3	CW	Poor wind direction, nearest turbine not PDN
V2616	SWEC Participating Vacant Lot	4.5	761	SWEC T004	39.3	CW	Poor wind direction, nearest turbine not PDN
R0081	Residence	4.5	783	SWEC T015	39.3	CW	Poor wind direction, nearest turbine not PDN
V2685	Vacant Lot	4.5	653	PDNWP T518	39.3	CW	Poor wind direction
R0206	Residence	1.5	639	PDNWP T528	39.3	CW	Poor wind direction
R0227	Residence	1.5	572	PDNWP T534	39.3	CW	Poor wind direction
R0222	Residence	1.5	555	PDNWP T533	39.3	CW	Poor wind direction
R0067	Residence	4.5	750	SWEC T004	39.2	CW	Poor wind direction, nearest turbine not PDN
R0182	SWEC Participating Receptor	4.5	643	PDNWP T523	39.2	CW	Poor wind direction
R0241	Residence	4.5	560	PDNWP T533	39.2	DW	High ambient noise



Receptor ID	Receptor Type	Height	Distance from Receptor to Source (m)	Nearest Turbine	Predicted Impact (Assessment)	Wind Direction	Added notes
R0488	Residence	4.5	686	PDNWP T552	39.2	DW	Redundant to R487
R0441	Residence	4.5	618	PDNWP T550	39.1	CW	Poor wind direction
R0002	SWEC Participating Receptor	4.5	802	SWEC T020	39.1	CW	Poor wind direction, nearest turbine not PDN
R0418	Residence	4.5	793	PDNWP T548	39.1	CW	Poor wind direction
R1308	Residence	4.5	587	PDNWP T408	39.1	CW	Poor wind direction
V2490	Vacant Lot	4.5	725	SWEC T012	39.1	CW	Poor wind direction, nearest turbine not PDN
R0125	Residence	4.5	681	SWEC T061	39.0	CW	Poor wind direction, nearest turbine not PDN
R0234	Residence	4.5	576	PDNWP T536	39.0	CW	Poor wind direction
R1168	Residence	4.5	758	PDNWP T548	39.0	CW	Poor wind direction
R1765	Residence	4.5	750	SWEC T012	39.0	CW	Poor wind direction, nearest turbine not PDN
V2491	Vacant Lot	4.5	751	SWEC T012	39.0	CW	Poor wind direction, nearest turbine not PDN
R0233	Residence	1.5	639	PDNWP T533	39.0	CW	Poor wind direction
R0401	Residence	4.5	579	PDNWP T541	38.9	CW	Poor wind direction
R0430	SWEC Participating Receptor	4.5	688	SWEC T026	38.9	UW	Poor wind direction, nearest turbine not PDN
V2744	SWEC Participating Vacant Lot	4.5	695	PDNWP T523	38.9	CW	Poor wind direction

Receptor ID	Receptor Type	Height	Distance from Receptor to Source (m)	Nearest Turbine	Predicted Impact (Assessment)	Wind Direction	Added notes
R0189	Residence	4.5	600	PDNWP T523	38.9	CW	Poor wind direction
V2403	Vacant Lot	4.5	698	PDNWP T407	38.9	CW	Poor wind direction
R0173	Residence	4.5	756	PDNWP T518	38.9	CW	Poor wind direction
V2733	Vacant Lot	4.5	555	PDNWP T540	38.9	UW	Poor wind direction
V2408	Vacant Lot	4.5	551	PDNWP T414	38.9	CW	Poor wind direction
R0469	Residence	1.5	677	PDNWP T546	38.9	CW	Poor wind direction
V2810	Vacant Lot	4.5	693	PDNWP T541	38.8	CW	Poor wind direction
R0294	Residence	4.5	602	PDNWP T536	38.8	CW	Poor wind direction
R0295	Residence	4.5	608	PDNWP T536	38.8	CW	Poor wind direction
V2808	SWEC Participating Vacant Lot	4.5	639	SWEC T026	38.8	CW	Poor wind direction, nearest turbine not PDN
R0403	Residence	4.5	723	PDNWP T541	38.8	CW	Poor wind direction
R0483	Residence	4.5	697	PDNWP T554	38.8	CW	Poor wind direction
R1314	Residence	1.5	572	PDNWP T409	38.8	CW	Poor wind direction
R0457	Residence	1.5	594	PDNWP T546	38.8	CW	Poor wind direction
V2811	Vacant Lot	4.5	750	PDNWP T541	38.7	CW	Poor wind direction
V2307	Vacant Lot	4.5	623	PDNWP T408	38.7	CW	Poor wind direction
V2614	Vacant Lot	4.5	483	PDNWP TR101	38.7	UW	Poor wind direction
V2306	Vacant Lot	4.5	636	PDNWP T408	38.6	CW	Poor wind direction
V2308	Vacant Lot	4.5	623	PDNWP T408	38.6	CW	Poor wind direction
V2309	Vacant Lot	4.5	622	PDNWP T408	38.6	CW	Poor wind direction
V2310	Vacant Lot	4.5	623	PDNWP T408	38.6	CW	Previously measured, high ambient noise

Receptor ID	Receptor Type	Height	Distance from Receptor to Source (m)	Nearest Turbine	Predicted Impact (Assessment)	Wind Direction	Added notes
R1374	Residence	4.5	561	PDNWP T501	38.6	UW	Poor wind direction
R0246	Residence	4.5	744	PDNWP T535	38.6	CW	Poor wind direction
V2311	Vacant Lot	4.5	626	PDNWP T408	38.6	CW	Poor wind direction
V2312	Vacant Lot	4.5	629	PDNWP T408	38.6	CW	Poor wind direction
R0124	SWEC Participating Receptor	4.5	592	SWEC T061	38.6	CW	Poor wind direction, nearest turbine not PDN
R0166	Residence	4.5	631	PDNWP T523	38.5	CW	Poor wind direction
P0307	PDN Participating Receptor	4.5	572	PDNWP T538	38.5	CW	Participating
V2313	Vacant Lot	4.5	634	PDNWP T408	38.5	CW	Poor wind direction
V2698	Vacant Lot	4.5	571	PDNWP T527	38.5	CW	Poor wind direction
R0413	Residence	4.5	691	PDNWP T541	38.5	DW	High ambient noise
R0409	Residence	4.5	792	PDNWP T540	38.5	CW	Poor wind direction
R0303	Residence	4.5	754	PDNWP T537	38.5	DW	Declined land access
V2727	Vacant Lot	4.5	626	PDNWP T558	38.5	DW	Declined land access
R0188	Residence	1.5	793	PDNWP T524	38.5	CW	Poor wind direction
R0471	Residence	1.5	689	PDNWP T554	38.5	CW	Poor wind direction
R1284	Residence	1.5	670	PDNWP T407	38.5	CW	Poor wind direction
R0433	Residence	1.5	570	PDNWP T543	38.5	CW	Poor wind direction
R1383	Residence	4.5	606	PDNWP T503	38.4	CW	Poor wind direction
V2314	Vacant Lot	4.5	646	PDNWP T408	38.4	CW	Poor wind direction
R1337	Residence	4.5	599	PDNWP T413	38.4	CW	Poor wind direction
P0209	PDN Participating Receptor	4.5	644	PDNWP T527	38.4	CW	Participating

Receptor ID	Receptor Type	Height	Distance from Receptor to Source (m)	Nearest Turbine	Predicted Impact (Assessment)	Wind Direction	Added notes
R0117	Residence	4.5	751	SWEC T061	38.4	UW	Poor wind direction, nearest turbine not PDN
R0033	Residence	4.5	781	SWEC T003	38.3	CW	Poor wind direction, nearest turbine not PDN
V2684	Vacant Lot	4.5	568	PDNWP T519	38.3	UW	Poor wind direction
V2814	Vacant Lot	4.5	694	SWEC T026	38.3	CW	Poor wind direction, nearest turbine not PDN
R0122	Residence	4.5	592	PDNWP T513	38.3	DW	High ambient noise
V2699	Vacant Lot	4.5	606	PDNWP T532	38.3	CW	Poor wind direction
V2730	Vacant Lot	4.5	670	PDNWP T536	38.3	CW	Poor wind direction
R0322	Residence	1.5	557	PDNWP T558	38.3	DW	High ambient noise
R0025	Residence	1.5	558	SWEC T014	38.3	DW	High ambient noise, nearest turbine not PDN
P0477	PDN Participating Receptor	1.5	575	PDNWP T554	38.3	CW	Participating
V2820	Vacant Lot	4.5	754	PDNWP T540	38.2	DW	Selected Receptor



---

**End of Report**

---